



NATIONAL GRID CORPORATION OF THE PHILIPPINES

Power Restoration Update

Tropical Storm: SENDONG

As of 19 December 2011, 10:00AM

For media inquiries, please contact:

Atty. Cynthia P. Alabanza, Spokesperson (cpalabanza@ngcp.ph/09175707884);

Jennifer M. de Jesus, Head Office CorpComm (corpcomm@ngcp.ph/09175874109)

For regular updates, you may follow us on Twitter at @NGCP_ALERT, or connect with us on Facebook through www.facebook.com/1NGCP.

The National Grid Corporation of the Philippines (NGCP) has restored all its 69-kV transmission lines affected by Tropical Storm Sendong, except the Bislig-San Fernando-Barobo line in Surigao del Sur which remains de-energized and under line patrol.

NGCP assures the public that it is ready to implement similar preparations and precautions to minimize the impact of succeeding typhoons on NGCP operation and facilities. ###

RESTORED FACILITIES:

Visayas (Samar-Leyte Area)

FACILITY: Tolosa – Mabuhay 69-kV Line

AFFECTED CUSTOMERS/ AREAS: DORELCO

STATUS: Line tripped on 15Dec, 11:46PM. Restored on 15Dec, 11:46AM.

FACILITY: Calbayog - Catarman Feeder 69-kV Line

AFFECTED CUSTOMERS/ AREAS: SAMELCO 1, NORSAMELCO (partial)

STATUS: Line tripped on 16Dec, 3:10AM. Restored on 16Dec, 11:17AM.

FACILITY: SOGOD - ST. BERNARD 69-kV Line

AFFECTED CUSTOMERS/ AREAS: SOLECO (Bontoc & Himayangan)

STATUS: Line tripped on 16Dec, 2:45PM. Restored on 16Dec, 2:49PM.

FACILITY: TOLOSA - MABUHAY 69-kV Line

AFFECTED CUSTOMERS/ AREAS: DORELCO (Tolosa)

STATUS: Line tripped on 16Dec, 3:36PM. Restored on 17Dec, 6:53AM.

FACILITY: CATARMAN - BOBOLOSAN 69-kV Line

AFFECTED CUSTOMERS/ AREAS: NORSAMELCO (Bobolosan)

STATUS: Line tripped on 16Dec, 8:06PM. Restored on 18Dec, 7:03PM.

Visayas (Bacolod Area)

FACILITY: Bacolod - San Enrique 69-kV Line

AFFECTED CUSTOMERS/ AREAS: NOCECO, DBI, CENECO

STATUS: Line tripped on 16Dec, 6:27AM. Restored on 16Dec, 6:34AM.

FACILITY: Maricalum-NOCECO (Cauayan) 69-kV Line

AFFECTED CUSTOMERS/ AREAS: NOCECO

STATUS: Line tripped on 16Dec, 8:53PM. Restored on 16Dec, 8:56PM.

FACILITY: Bacong-Siaton 69-kV Line

AFFECTED CUSTOMERS/ AREAS: NORECO 2

STATUS: Line tripped on 17Dec, 2:30AM. Restored on 17Dec, 11:41AM.

Line tripped on 17Dec, 11:50AM. Restored on 17Dec, 12:25PM.

Line tripped on 17Dec, 1:11PM. Restored on 17Dec, 3:04PM.



NATIONAL GRID CORPORATION OF THE PHILIPPINES

FACILITY: Amlan - Dumaguete 69-kV Line
AFFECTED CUSTOMERS/ AREAS: NORECO 2
STATUS: Line tripped on 17Dec, 8:08AM. Restored on 17Dec, 8:15AM.

Visayas (Panay Area)

FACILITY: Nabas-Caticlan 69-kV Line
AFFECTED CUSTOMERS/ AREAS: AKELCO (Boracay Island)
STATUS: Line tripped on 16Dec, 7:22PM. Restored on 16Dec, 7:33PM.

Mindanao (Lanao Area)

FACILITY: MC-KIWALAN 69-kV Line
AFFECTED CUSTOMERS/ AREAS: ILPI
STATUS: Line tripped on 17Dec, 12:04AM. Restored on 18Dec, 11:11AM.

FACILITY: LUGAIT-KIWALAN 69-kV Line
AFFECTED CUSTOMERS/ AREAS: PILMICO Foods Corp.
STATUS: Line tripped on 18Dec, 9:58AM. Restored on 18Dec, 11:11AM.

Mindanao (Northcentral Area)

FACILITY: JASAAN-BALINGOAN 69-kV Line
AFFECTED CUSTOMERS/ AREAS: MORESCO 2, CAMELCO
STATUS: Line tripped on 16Dec, 9:55PM. Restored on 17Dec, 3:22PM.

Mindanao (Northeastern Area)

FACILITY: SAN FRANCISCO-TANDAG 69-kV Line
AFFECTED CUSTOMERS/ AREAS: SURSECO 2
STATUS: Line tripped on 16Dec, 3:58PM. Restored on 17Dec, 3:51PM.

FACILITY: BISLIG-GUICOB-CATEEL-BAGANGA 69-kV Line
AFFECTED CUSTOMERS/ AREAS: DORECO
STATUS: Line tripped on 16Dec, 3:33PM. Restored on 17Dec, 8:08AM.

FACILITY: BISLIG-TRENTO 69-kV Line
AFFECTED CUSTOMERS/ AREAS: ASELCO
STATUS: Line tripped on 16Dec, 4:07PM. Restored on 17Dec, 5:10PM.

FACILITY: BISLIG-SANFERNANDO-BAROBO 69-kV Line
AFFECTED CUSTOMERS/ AREAS: SURSECO 1
STATUS: Line tripped on 16Dec, 4:18PM. Restoration ongoing.