



NATIONAL GRID CORPORATION OF THE PHILIPPINES

Power Restoration Update

Tropical Storm: JUANING

As of 27 July 2011, 5:00AM

Contact Persons:	Atty. Cynthia Perez-Alabanza	cpalabanza@ngcp.ph	09175707884
	Jennifer de Jesus	jmdejesus@ngcp.ph	09088654651
	Adrienne Mendoza	abmendoza@ngcp.ph	09183651240

NGCP FACILITY	Affected Customers / Areas	Status
230 kV Gumaca-Labo L2	No affected customer	Line tripped at 26 July, 2:21PM; Conducted patrol, however no possible cause of outage was found during inspection.
69 kV Sorsogon-Irosin	Sorsogon: SORECO 1 (Bulan, Irosin) SORECO 2 (Gubat)	Line tripped at 25 July, 11:19PM; For inspection; Major roads are passable but access roads to site are impassable due to flood.
69 kV Daraga-Sorsogon	Sorsogon: SORECO 1; SORECO 2 (Entire Province of Sorsogon)	Line tripped at 26 July, 2:44AM; Re-energized at 26 July, 3:22PM; Inspection on-going; Major roads are passable but access roads to site are impassable due to flood.
69 kV Daraga-Ligao	Albay: BIP; PHI; GFCC; ALECO (Ligao, Polangui)	Line tripped at 26 July, 1:40AM; For inspection; Major roads are impassable (Cullat, Bongalon, Balangibang, Lidong Padang, Balsa)
69 kV Tiwi-Malinao-Tabaco	Albay: ALECO (Tiwi, Malinao)	Line tripped at 26 July, 8:59AM; For inspection; Major roads are impassable (Cullat, Bongalon, Balangibang, Lidong Padang, Balsa)
69 kV Naga-Libmanan	Camarines Sur: CASURECO 1 (Pamplona, Libmanan, Sipocot)	Line tripped at 26 July, 7:23AM; Inspection on-going on toppled poles #62 and #63 at Cabugao, Milaor, CS; Major roads are impassable (Nabua, Baao)
69 kV Labo-Talisay	Camarines Norte: CANORECO (Talisay, Vinzons, Daet, Mercedes, Basud, San Vicente, Ruiz, Labo, Capalonga & Sta. Elena) Purity Ice Plant	Line tripped at 26 July, 10:30PM; Inspection on-going
69 kV Cabanatuan-Pantabangan	Nueva Ecija: NEECO II (Guimba, Quezon, Muñoz,) CLSU SAJELCO Pantabangan S/S	Auto tripped at 26 July, 08:05PM; Energized at 27 July, 01:06AM; After repair of cut jumper loop
69 kV	Nueva Ecija:	Manually tripped at 26 July, 12:05AM; Energized



NATIONAL GRID CORPORATION OF THE PHILIPPINES

Cabanatuan-Baler	NEECO II (Talavera) NEA MGT (Bongabon, Gen. Natividad) Aurora: AURELCO (San Luis)	at 27 July, 01:01AM
------------------	---	---------------------

Estimated time of restoration will be posted once available. For regular updates, you may follow us on Twitter at [@NGCP_alert](https://twitter.com/NGCP_alert), or connect with us on Facebook through www.facebook.com/1NGCP.





NATIONAL GRID CORPORATION OF THE PHILIPPINES

Quezon Ave. cor. BIR Rd., Diliman, Quezon City, Philippines
Telephone +632 981-2143 / +632 981-2142 . Fax +632 922-2684 . E-mail corpcomm@ngcp.ph