



NATIONAL GRID CORPORATION OF THE PHILIPPINES

Power Restoration Update

Tropical Storm: JUANING

As of 26 July 2011, 3:00 PM

NGCP FACILITY	Affected Areas	Status
69 kV Sorsogon-Irosin	SORECO 1 (Bulan, Irosin) SORECO 2 (Gubat)	Line tripped at 25 July, 11:19PM; For inspection; Major roads are passable but access roads to site are impassable due to flood.
69 kV Daraga-Sorsogon	SORECO 1; SORECO 2 (Entire Province of Sorsogon)	Line tripped at 26 July, 2:44AM; For inspection; Major roads are passable but access roads to site are impassable due to flood.
69 kV Daraga-Ligao	BIP; PHI; GFCC; ALECO (Ligao, Polangui)	Line tripped at 26 July, 1:40AM; For inspection; Major roads are impassable (Cullat, Bongalon, Balangibang, Lidong Padang, Balsa)
69 kV Daraga-Legaspi	ALECO (Washington, Bitano); ELVI, PMI	Line tripped at 26 July, 8:25AM; Re-energized at 26 July, 2:51PM; Inspection on-going; Major roads are impassable (Cullat, Bongalon, Balangibang, Lidong Padang, Balsa)
69 kV Tiwi-Malinao-Tabaco	ALECO (Tiwi, Malinao)	Line tripped at 26 July, 8:59AM; For inspection; Major roads are impassable (Cullat, Bongalon, Balangibang, Lidong Padang, Balsa)
69 kV Naga-Libmanan	CASURECO 1 (Pamplona, Libmanan, Sipocot)	Line tripped at 26 July, 7:23AM; Inspection on-going on toppled poles #62 and #63 at Cabugao, Milaor, CS; Major roads are impassable (Nabua, Baao)

Estimated time of restoration will be posted once available. For regular updates, you may follow us on Twitter at @NGCP_alert, or connect with us on facebook through www.facebook.com/1NGCP.



National Grid Corporation of the Philippines (NGCP)

Quezon Ave. cor. BIR Rd., Diliman, Quezon City, Philippines

Telephone +632 981-2143 / +632 981-2142 . Fax +632 922-2684 . E-mail corpcomm@ngcp.ph