



NATIONAL GRID CORPORATION OF THE PHILIPPINES

New Release

22 July 2011

Unscheduled power interruption in parts of Bohol

The National Grid Corporation of the Philippines (NGCP) has restored power transmission services to its customers in Bohol on July 21 after re-energizing the Ubay-Garcia Hernandez-Tagbilaran 69-kV Transmission Line.

Customers Bohol Electric Cooperative I (BOHECO I), Bohol Electric Cooperative II (BOHECO II), Philippine Mining Service Corp.–Bohol Plant, Marcela Farms, Inc., and Bohol Light Company, Inc. experienced a power interruption at 6:52 PM on July 21 when an insulator was detached from a transmission structure located in Barangay Banat-i, Tagbilaran.

The Ubay-Garcia Hernandez portion of the line was restored at 7:40 PM.

The Garcia Hernandez-Tagbilaran portion was restored with temporary correction at 9:03 PM.

Total restoration works for the entire length of the 69-kV transmission line were completed at 11:59 PM. ###

National Grid Corporation of the Philippines (NGCP)

Quezon Ave. cor. BIR Rd., Diliman, Quezon City, Philippines

Telephone +632 981-2143 / +632 981-2142 . Fax +632 922-2684 . E-mail corpcomm@ngcp.ph