



LUZON GRID 2025 Weekly Demand, Supply and Operating Margin Profile



2025	JANUARY TO JUNE 2025																											
	Dec 30	Jan 06	Jan 13	Jan 20	Jan 27	Feb 03	Feb 10	Feb 17	Feb 24	Mar 03	Mar 10	Mar 17	Mar 24	Mar 31	Apr 07	Apr 14	Apr 21	Apr 28	May 05	May 12	May 19	May 26	Jun 02	Jun 09	Jun 16	Jun 23		
	Jan 05	Jan 12	Jan 19	Jan 26	Feb 02	Feb 09	Feb 16	Feb 23	Feb 30	Mar 09	Mar 16	Mar 23	Mar 30	Apr 06	Apr 13	Apr 20	Apr 27	May 04	May 11	May 18	May 25	Jun 01	Jun 08	Jun 15	Jun 22	Jun 29		
Available Generating Capacity (MW)	15,132	15,566	15,801	15,025	15,655	14,831	14,817	15,595	15,592	16,152	16,058	16,353	16,571	16,832	16,795	16,683	16,722	16,740	16,612	16,679	16,595	16,775	15,754	15,375	15,618	15,543		
Thermal	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
Coal	7,058	7,058	7,368	6,850	7,518	7,450	6,968	7,557	7,557	7,862	7,862	8,282	8,432	8,748	8,748	8,748	8,748	8,748	8,748	8,748	8,748	8,748	7,906	7,606	7,606	7,606		
Gas Turbine/Diesel	746	746	746	746	746	736	736	736	679	672	687	746	746	746	746	746	746	746	746	746	746	746	746	746	746	746		
Combined Cycle/NatGas	4,020	4,636	4,636	4,636	4,371	4,371	4,636	4,696	4,696	4,696	4,696	4,653	4,653	4,696	4,696	4,696	4,696	4,696	4,696	4,696	4,696	4,696	4,696	4,696	4,696	4,696		
Geothermal	555	555	555	525	525	525	525	525	525	525	525	525	525	555	555	500	413	500	555	555	549	549	549	555	555	555		
HVDC	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
Wind Farm	303	243	191	47	210	243	98	322	233	135	229	51	98	196	215	126	98	98	37	37	28	79	65	56	33	42		
Solar	356	380	356	309	380	404	285	380	475	499	332	451	475	451	404	427	404	499	475	475	404	522	427	356	475	380		
BESS	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
Biomass	95	95	95	95	91	97	101	101	101	107	107	107	107	107	107	107	107	107	107	107	107	107	107	107	107	107		
Hydro	1,999	1,854	1,854	1,819	1,815	1,007	1,469	1,279	1,327	1,657	1,621	1,538	1,536	1,333	1,325	1,334	1,511	1,347	1,249	1,316	1,318	1,328	1,258	1,254	1,401	1,412		
System Peak Demand (MW)	10,785	11,369	11,516	11,481	11,767	11,800	11,901	12,074	12,229	12,349	12,452	12,774	12,854	12,924	13,096	13,374	14,409	14,646	14,769	14,719	14,482	14,339	14,293	14,242	14,160	13,784		
Operating Margin (MW)	4,097	3,947	4,035	3,294	3,638	2,781	2,666	3,271	3,113	3,553	3,357	3,329	3,468	3,658	3,449	3,060	2,063	1,844	1,593	1,710	1,863	2,186	1,212	883	1,207	1,510		
Req'd Regulating Reserve	431	455	461	459	471	472	476	483	489	494	498	511	514	517	524	535	576	586	591	589	579	574	572	570	566	551		
Req'd Contingency Reserve	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668		
Req'd Dispatchable Reserve	668	668	668	647	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668		
HVDC Export (MW)	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250		

- Peak Demand Forecast at 14,769 MW to occur in May 2025 based from the DOE Peak Demand Forecast 2020-2040
- Preventive Maintenance of Power Plants considered.
- Embedded Generators considered.
- Capacity Factor for VRE Plants used: average of 16% for Solar and 30% for Wind (average of actual capacity for 3 years: 2021 to 2023): Based on 24 hours
- Consideration of additional capacities of new VRE Plants
- The operating margin per week shown on the graph is based on the forecasted peak demand per week and its coincident available capacity.
- The Loss of Load Probability (LOLP) shown on the graph is derived with the consideration of capacity sharing among three regions and based on hourly projected peak demand. Hourly LOLP measures the probability that, during a specific hour, the electricity demand will exceed the available generation capacity.
- The Probability of Yellow and Red Levels shown on the graph are derived with the consideration of capacity sharing among three regions and based on daily projected peak demand. Daily Probability of Yellow and Red Levels measures the probability that, at any time during a particular day, there will be at least one hour where the demand exceeds the supply together with the regulating and contingency required reserve level.
- Capacity addition per updates from DOE Luzon Power Committed Project as of June 30, 2024:
 - 9.1 Masinloc Power Plant - Unit 4 (350 MW) - target date of commercial operation: August 2025
 - 9.2 11.04 MW Capas Bunker C-Fired Diesel Power Plant (11.04 MW) - target date of commercial operation: February 2025
 - 9.3 Batangas Combined Cycle Power Plant - Phase 1, Unit 3 (440 MW) - target date of commercial operation: March 2025
 - 9.4 Ibulao 1 Hydroelectric Power Project (7.6MW) - target date of commercial operation: March 2025
 - 9.5 Dupina Hydroelectric Power Project (4.8MW) - target date of commercial operation: June 2025
 - 9.6 Sablan 1 Hydroelectric Power Project (20 MW) - target date of commercial operation: November 26, 2025
 - 9.7 Daet Hydroelectric Power Project (5 MW) - target date of commercial operation: December 2025
 - 9.8 Dipalo Hydroelectric Power Project (4.15 MW) - target date of commercial operation: December 2025
 - 9.9 Rangas Hydroelectric Power Project (2.4 MW) - target date of commercial operation: December 2025
 - 9.10 Asin-Hungdan Hydroelectric Power Project (9.8 MW) - target date of commercial operation: January 2025
 - 9.11 Tumauini Hydroelectric Power Project (11.30 MW) - target date of commercial operation: January 2025
 - 9.12 5.082-MW Biomass Power Plant Project (5.082MW) - target date of commercial operation: August 2025
 - 9.13 Talugtug Solar Power Project (99.80 MW) - target date of commercial operation: March 2025
 - 9.14 Santa Rosa Nueva Ecija 2 Solar Power Project Phase 1A (33.348MW) - target date of commercial operation: August 2025
 - 9.15 Labrador Solar Power Plant Project (200MW) - target date of commercial operation: October 2025
 - 9.16 PAVI Green Naga Solar Power Plant Project (40.40 MW) - target date of commercial operation: December 2025
 - 9.17 Concepcion Tarlac 2 Solar Power Project (200MW) - target date of commercial operation: December 2025
 - 9.18 Santa Rosa Nueva Ecija 2 Solar Power Project Phase 1B (108.40MW) - target date of commercial operation: December 2025
- 9.19 Santa Rosa Nueva Ecija 2 Solar Power Project Phase 2 (171.6MW) - target date of commercial operation: December 2025
- 9.20 Tayabas Solar Power Project (450MW) - target date of commercial operation: December 2025
- 9.21 Sapang Balen Solar 1 Power Project (Phase 1) (79.20MW) - target date of commercial operation: December 2025
- 9.22 Sapang Balen Solar 1 Power Project (Phase 2) (79.20MW) - target date of commercial operation: December 2025
- 9.23 PAVI Green San Vicente Solar Power Plant Project (28.60MW) - target date of commercial operation: December 2025
- 9.24 Development of 50MW Ground Mounted Solar Power Plant (50MW) - target date of commercial operation: December 2025
- 9.25 San Pablo Solar Power Project Phase 1 (49.40MW) - target date of commercial operation: December 2025
- 9.26 Limbaun Solar Power Project (28MW) - target date of commercial operation: December 2025
- 9.27 Bugallon Solar Power Project (18.56MW) - target date of commercial operation: December 2025
- 9.28 Samal Solar Power Project (48.118MW) - target date of commercial operation: December 2025
- 9.29 Balaoi and Caunayan Wind Power Project (160MW) - target date of commercial operation: March 01, 2025
- 9.30 Talin Wind Power Project (218.75MW) - target date of commercial operation: June 30, 2025
- 9.31 Tanay Wind Power Project (85.8MW) - target date of commercial operation: November 27, 2025
- 9.32 Alabat Wind Power Project (62.40MW) - target date of commercial operation: November 28, 2025
- 9.33 Rizal Wind Power Project (90MW) - target date of commercial operation: December 15, 2025
- 9.34 Caparisan II Wind Power Project (70MW) - target date of commercial operation: December 25, 2025
- 9.35 Calatagan Wind Power Project (30MW) - target date of commercial operation: December 25, 2025

LUZON GRID 2025 Weekly Demand, Supply and Operating Margin Profile



2025	JULY TO DECEMBER 2025																											
	Jun 30	Jul 07	Jul 14	Jul 21	Jul 28	Aug 04	Aug 11	Aug 18	Aug 25	Sep 01	Sep 08	Sep 15	Sep 22	Sep 29	Oct 06	Oct 13	Oct 20	Oct 27	Nov 03	Nov 10	Nov 17	Nov 24	Dec 01	Dec 08	Dec 15	Dec 22		
	Jul 06	Jul 13	Jul 20	Jul 27	Aug 03	Aug 10	Aug 17	Aug 24	Aug 31	Sep 07	Sep 14	Sep 21	Sep 28	Oct 05	Oct 12	Oct 19	Oct 26	Nov 02	Nov 09	Nov 16	Nov 23	Nov 30	Dec 07	Dec 14	Dec 21	Dec 28		
Available Generating Capacity (MW)	15,898	14,848	14,574	15,500	15,015	14,492	14,459	14,316	14,974	15,134	15,134	15,656	16,200	15,535	16,234	16,319	15,805	15,567	15,175	15,167	15,738	15,049	15,872	15,867	16,067	17,092		
Thermal	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
Coal	8,138	7,756	7,756	7,906	7,485	7,192	7,192	7,342	7,005	7,005	7,005	7,644	8,138	7,803	7,953	7,803	7,563	7,251	7,396	7,396	7,401	6,754	7,329	7,329	7,419	8,066		
Gas Turbine/Diesel	734	674	672	693	746	742	736	740	740	740	740	742	742	740	746	740	740	735	735	746	746	746	746	724	736	746		
Combined Cycle/NatGas	4,396	4,096	3,770	4,438	4,438	3,838	3,838	3,583	4,438	4,438	4,438	4,345	4,431	4,166	4,165	4,431	4,344	4,344	3,925	3,925	4,432	4,432	4,372	4,432	4,432	4,696		
Geothermal	555	348	455	455	425	425	425	455	555	555	555	511	511	511	555	555	555	555	512	512	442	442	555	555	555	555		
HVDC	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
Wind Farm	51	28	14	103	131	173	51	9	51	163	163	65	131	28	98	168	149	229	112	205	261	187	224	205	350	360		
Solar	356	427	332	332	309	356	451	427	404	309	309	427	332	404	451	356	332	356	475	356	404	427	404	380	332	427		
BESS	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
Biomass	107	107	107	107	107	83	83	83	101	99	99	99	99	99	99	107	107	107	107	107	107	107	107	107	107	107		
Hydro	1,561	1,412	1,468	1,466	1,375	1,682	1,682	1,677	1,679	1,824	1,824	1,823	1,817	1,785	2,159	2,159	2,015	1,992	1,914	1,920	1,946	1,954	2,136	2,136	2,136	2,136		
System Peak Demand (MW)	13,720	13,680	13,548	13,524	13,511	13,518	13,541	13,542	13,583	13,577	13,577	13,596	13,634	13,540	13,500	13,421	13,365	13,326	13,318	13,324	13,387	13,254	13,194	13,100	12,704	12,377		
Operating Margin (MW)	1,929	918	776	1,726	1,254	723	668	524	1,141	1,306	1,306	1,810	2,316	1,745	2,484	2,648	2,440	2,241	1,607	1,593	2,101	1,544	2,427	2,518	3,113	4,464		
Req'd Regulating Reserve	549	547	542	541	540	541	542	542	543	543	543	544	545	542	540	537	535	533	533	533	535	530	528	524	508	495		
Req'd Contingency Reserve	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668		
Req'd Dispatchable Reserve	668	668	668	668	668	647	647	647	647	647	647	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668		
HVDC Export (MW)	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	0	0	250	250	250	250	250	250	250	250		


- Peak Demand Forecast at 14,769 MW to occur in May 2025 based from the DOE Peak Demand Forecast 2020-2040
- Preventive Maintenance of Power Plants considered.
- Embedded Generators considered.
- Capacity Factor for VRE Plants used: average of 16% for Solar and 30% for Wind (average of actual capacity for 3 years: 2021 to 2023); Based on 24 hours
- Consideration of additional capacities of new VRE Plants
- The operating margin per week shown on the graph is based on the forecasted peak demand per week and its coincident available capacity.
- The Loss of Load Probability (LOLP) shown on the graph is derived with the consideration of capacity sharing among three regions and based on hourly projected peak demand. Hourly LOLP measures the probability that, during a specific hour, the electricity demand will exceed the available generation capacity.
- The Probability of Yellow and Red Levels shown on the graph are derived with the consideration of capacity sharing among three regions and based on daily projected peak demand. Daily Probability of Yellow and Red Levels measures the probability that, at any time during a particular day, there will be at least one hour where the demand exceeds the supply together with the regulating and contingency required reserve level.
- Capacity addition per updates from DOE Luzon Power Committed Project as of June 30, 2024:
 - Masinloc Power Plant - Unit 4 (350 MW) - target date of commercial operation: August 2025
 - 11.04 MW Capas Bunker C-Fired Diesel Power Plant (11.04 MW) - target date of commercial operation: February 2025
 - Batangas Combined Cycle Power Plant - Phase 1, Unit 3 (440 MW) - target date of commercial operation: March 2025
 - Ibulao 1 Hydroelectric Power Project (7.6MW) - target date of commercial operation: March 2025
 - Duplaga Hydroelectric Power Project (4.8MW) - target date of commercial operation: June 2025
 - Sablan 1 Hydroelectric Power Project (20 MW) - target date of commercial operation: November 26, 2025
 - Daet Hydroelectric Power Project (5 MW) - target date of commercial operation: December 2025
 - Dipalo Hydroelectric Power Project (4.15 MW) - target date of commercial operation: December 2025
 - Rangas Hydroelectric Power Project (2.4 MW) - target date of commercial operation: December 2025
 - Asin-Hungduan Hydroelectric Power Project (9.8 MW) - target date of commercial operation: January 2025
 - Tumauni Hydroelectric Power Project (11.30 MW) - target date of commercial operation: January 2025
 - 5.082-MW Biomass Power Plant Project (5.082MW) - target date of commercial operation: August 2025
 - Talugtug Solar Power Project (99.80 MW) - target date of commercial operation: March 2025
 - 14 Santa Rosa Nueva Ecija 2 Solar Power Project Phase 1A (33.348MW) - target date of commercial operation: August 2025
 - 15 Labrador Solar Power Plant Project (200MW) - target date of commercial operation: October 2025
 - 16 PAVI Green Naga Solar Power Plant Project (40.40 MW) - target date of commercial operation: December 2025
 - 17 Concepcion Tarlac 2 Solar Power Project (200MW) - target date of commercial operation: December 2025
 - 18 Santa Rosa Nueva Ecija 2 Solar Power Project Phase 1B (108.40MW) - target date of commercial operation: December 2025
- Naga-Ormoc HVDC maintenance schedule is on October 23 - 29, 2025
 - Santa Rosa Nueva Ecija 2 Solar Power Project Phase 2 (171.6MW) - target date of commercial operation: December 2025
 - Tayabas Solar Power Project (450MW) - target date of commercial operation: December 2025
 - Sapang Balen Solar 1 Power Project (Phase 1) (79.20MW) - target date of commercial operation: December 2025
 - Sapang Balen Solar 1 Power Project (Phase 2) (79.20MW) - target date of commercial operation: December 2025
 - PAVI Green San Vicente Solar Power Plant Project (28.60MW) - target date of commercial operation: December 2025
 - Development of 50MW Ground Mounted Solar Power Plant (50MW) - target date of commercial operation: December 2025
 - San Pablo Solar Power Project Phase 1 (49.40MW) - target date of commercial operation: December 2025
 - Limbaan Solar Power Project (28MW) - target date of commercial operation: December 2025
 - Bugallan Solar Power Project (18.56MW) - target date of commercial operation: December 2025
 - Samal Solar Power Project (48.118MW) - target date of commercial operation: December 2025
 - Balaoi and Caunayan Wind Power Project (160MW) - target date of commercial operation: December 01, 2025
 - Talim Wind Power Project (218.75MW) - target date of commercial operation: June 30, 2025
 - Tanay Wind Power Project (85.8MW) - target date of commercial operation: November 27, 2025
 - Alabat Wind Power Project (62.40MW) - target date of commercial operation: November 28, 2025
 - Rizal Wind Power Project (90MW) - target date of commercial operation: December 15, 2025
 - Caparisan II Wind Power Project (70MW) - target date of commercial operation: December 25, 2025
 - Calatagan Wind Power Project (30MW) - target date of commercial operation: December 25, 2025



VISAYAS GRID

2025 Weekly Demand, Supply and Operating Margin Profile

Afternoon Peak Scenario with 450 MW Import from Mindanao




2025	JANUARY TO JUNE 2025																											
	Dec 30	Jan 06	Jan 13	Jan 20	Jan 27	Feb 03	Feb 10	Feb 17	Feb 24	Mar 03	Mar 10	Mar 17	Mar 24	Mar 31	Apr 07	Apr 14	Apr 21	Apr 28	May 05	May 12	May 19	May 26	Jun 02	Jun 09	Jun 16	Jun 23		
	Jan 05	Jan 12	Jan 19	Jan 26	Feb 02	Feb 09	Feb 16	Feb 23	Mar 02	Mar 09	Mar 16	Mar 23	Mar 30	Apr 06	Apr 13	Apr 20	Apr 27	May 04	May 11	May 18	May 25	Jun 01	Jun 08	Jun 15	Jun 22	Jun 29		
Available Generating Capacity (MW)	2,975	2,895	2,861	2,707	2,806	2,748	2,823	2,764	2,726	2,743	2,701	2,584	2,790	3,050	3,050	3,041	3,050	2,976	2,958	2,958	2,958	2,946	2,941	2,941	2,927	2,941		
Thermal	1,321	1,321	1,218	1,049	1,152	1,152	1,152	1,152	1,152	1,157	1,054	1,054	1,136	1,321	1,321	1,321	1,321	1,321	1,321	1,321	1,321	1,321	1,321	1,321	1,321	1,321		
Geothermal	763	763	763	763	763	688	763	716	666	666	727	727	727	800	800	800	800	800	800	800	800	800	800	800	800	800		
Diesel	332	252	321	336	320	336	336	324	324	336	336	219	336	336	336	336	336	330	330	330	330	330	330	330	330	330		
Power Barges	52	52	52	52	52	52	52	52	45	45	45	45	52	52	52	52	52	52	52	52	52	52	52	52	52	52		
Hydro	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	63	73	73	73	73	73	73	73	73	73	73		
Biomass	267	267	267	267	267	267	267	267	267	267	267	267	267	267	267	267	267	232	214	214	214	214	208	208	208	208		
Solar	120	120	120	120	142	142	142	142	157	157	157	157	157	168	168	168	168	156	156	156	156	135	135	135	121	135		
Wind	48	48	48	48	39	39	39	39	43	43	43	43	43	34	34	34	34	13	13	13	13	22	23	23	23	23		
BESS	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
System Peak Demand (MW)	2,244	2,173	2,312	2,288	2,229	2,294	2,263	2,601	2,601	2,521	2,662	2,770	2,799	2,835	2,835	2,935	3,049	3,007	3,096	3,109	3,111	2,948	2,950	2,950	2,818	2,858		
Operating Margin (MW)	731	722	549	419	577	454	560	163	125	222	39	-186	-9	215	215	106	1	-31	-138	-151	-153	-2	-9	-9	109	83		
Stranded Capacity (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
Net Operating Margin (MW)	731	722	549	419	577	454	560	163	125	222	39	0	0	215	215	106	1	0	0	0	0	0	0	0	109	83		
Req'd Regulating Reserve	90	87	92	92	89	92	91	104	104	101	106	111	112	113	113	117	122	120	124	124	124	118	118	118	113	114		
Req'd Contingency Reserve	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169		
Req'd Dispatchable Reserve	169	169	169	150	150	150	150	150	150	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169		
Available Import from Luzon (HVDC)	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250		
Available Import from Mindanao (MVIP)	450	450	450	450	450	450	450	450	450	450	450	450	450	450	450	380	450	450	449	450	450	450	450	450	450	450		

- Peak Demand Forecast at 3,111 MW to occur in May 2025 based from the DOE Peak Demand Forecast 2020-2040.
- Preventive Maintenance of Power Plants considered.
- Embedded Generators considered.
- Capacity Factor for VRE Plants used: average of 17% for Solar and 22% for Wind (average of actual capacity for the previous year): Based on 24 hours
- The operating margin per week shown on the graph is based on the forecasted afternoon peak demand per week and its coincident available capacity.
- The Loss of Load Probability (LOLP) shown on the graph is derived with the consideration of capacity sharing among three regions and based on hourly projected peak demand. Hourly LOLP measures the probability that, during a specific hour, the electricity demand will exceed the available generation capacity.
- The Probability of Yellow and Red Levels shown on the graph are derived with the consideration of capacity sharing among three regions and based on daily projected peak demand. Daily Probability of Yellow and Red Levels measures the probability that, at any time during a particular day, there will be at least one hour where the demand exceeds the supply together with the regulating and contingency required reserve level.
- Capacity addition per updates from DOE Visayas Power Committed Project as of June 30, 2024:
 - Biliran Geothermal Plant Project (Phase 2) (6MW) - target date of commercial operation: January 2025
 - Mahanagdong Geothermal Brine Optimization Power Plant (28MW) - target date of commercial operation: September 2025
 - Bao Hydroelectric Power Project (2.0MW) - target date of commercial operation: July 2025
 - 40-MW Biomass Cogeneration Plant (30-MW Expansion Project) (30MW) - target date of commercial operation: May 2025
 - San Isidro Solar Power Project (226.842MW) - target date of commercial operation: June 2025
 - Kananga-Ormoc Solar Power Project (300MW) - target date of commercial operation: December 2025
 - Dagohoy Solar Power Project (20.622MW) - target date of commercial operation: February 2025
 - Nabas Wind Power Project (13.20MW) - target date of commercial operation: May 1, 2025
- Naga-Ormoc HVDC maintenance schedule is on October 23 - 29, 2025
- Lala-Dumanjug HVDC maintenance schedule is on July 23 - 29, 2025 for Pole 1, August 21 - 27, 2025 for Pole 2, and September 24 - 30, 2025 for Bipole



VISAYAS GRID 2025 Weekly Demand, Supply and Operating Margin Profile Afternoon Peak Scenario with 450 MW Import from Mindanao




2025	JULY TO DECEMBER 2025																											
	Jun 30	Jul 07	Jul 14	Jul 21	Jul 28	Aug 04	Aug 11	Aug 18	Aug 25	Sep 01	Sep 08	Sep 15	Sep 22	Sep 29	Oct 06	Oct 13	Oct 20	Oct 27	Nov 03	Nov 10	Nov 17	Nov 24	Dec 01	Dec 08	Dec 15	Dec 22		
	Jul 06	Jul 13	Jul 20	Jul 27	Aug 03	Aug 10	Aug 17	Aug 24	Aug 31	Sep 07	Sep 14	Sep 21	Sep 28	Oct 05	Oct 12	Oct 19	Oct 26	Nov 02	Nov 09	Nov 16	Nov 23	Nov 30	Dec 07	Dec 14	Dec 21	Dec 28		
Available Generating Capacity (MW)	2,819	2,822	2,799	2,804	2,803	2,836	2,848	2,819	2,748	2,840	2,820	2,806	2,825	2,913	2,791	2,776	2,807	2,767	2,861	2,889	2,842	2,739	2,827	2,874	2,951	3,066		
Thermal	1,239	1,239	1,239	1,239	1,239	1,239	1,239	1,239	1,239	1,239	1,239	1,239	1,239	1,321	1,186	1,186	1,186	1,186	1,321	1,321	1,321	1,218	1,218	1,218	1,218	1,321		
Geothermal	800	800	800	794	794	794	800	800	714	800	780	760	767	767	780	780	800	735	735	770	710	710	735	735	800	800		
Diesel	302	313	274	309	293	293	300	277	300	256	256	256	267	277	282	268	287	270	235	235	235	235	235	282	288	300		
Power Barges	45	45	45	45	38	52	52	52	52	46	46	52	52	46	46	52	52	52	46	39	52	52	46	46	52	52		
Hydro	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73		
Biomass	200	208	208	200	208	208	208	208	208	267	267	267	267	267	267	267	267	267	267	267	267	267	267	267	267	267		
Solar	129	113	129	113	122	142	142	135	137	135	135	135	135	145	139	131	124	138	138	138	138	138	206	206	206	206		
Wind	31	31	31	31	35	35	35	35	25	25	25	25	25	19	19	19	19	47	47	47	47	47	47	47	47	47		
BESS	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
System Peak Demand (MW)	2,908	2,852	2,805	2,904	2,989	2,989	2,911	2,963	2,998	2,980	3,036	3,025	2,939	3,049	2,984	2,952	2,930	2,930	3,034	3,021	2,990	2,963	2,944	2,937	2,375	2,218		
Operating Margin (MW)	-89	-30	-6	-100	-186	-153	-63	-144	-250	-140	-216	-219	-114	-136	-193	-176	-123	-163	-173	-132	-148	-224	-117	-63	576	848		
Stranded Capacity (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
Net Operating Margin (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	576	848		
Req'd Regulating Reserve	116	114	112	116	120	120	116	119	120	119	121	121	118	122	119	118	117	117	121	121	120	119	118	117	95	89		
Req'd Contingency Reserve	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169		
Req'd Dispatchable Reserve	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169		
Available Import from Luzon (HVDC)	250	250	250	250	250	204	58	250	250	250	250	250	250	250	250	250	0	250	250	250	250	250	250	250	250	250		
Available Import from Mindanao (MVIP)	450	450	450	225	450	430	450	225	450	356	388	293	0	334	450	399	280	436	311	351	450	450	450	450	450	450		

- Peak Demand Forecast at 3,111 MW to occur in May 2025 based from the DOE Peak Demand Forecast 2020-2040.
- Preventive Maintenance of Power Plants considered.
- Embedded Generators considered.
- Capacity Factor for VRE Plants used: average of 17% for Solar and 22% for Wind (average of actual capacity for the previous year): Based on 24 hours
- The operating margin per week shown on the graph is based on the forecasted afternoon peak demand per week and its coincident available capacity.
- The Loss of Load Probability (LOLP) shown on the graph is derived with the consideration of capacity sharing among three regions and based on hourly projected peak demand. Hourly LOLP measures the probability that, during a specific hour, the electricity demand will exceed the available generation capacity.
- The Probability of Yellow and Red Levels shown on the graph are derived with the consideration of capacity sharing among three regions and based on daily projected peak demand. Daily Probability of Yellow and Red Levels measures the probability that, at any time during a particular day, there will be at least one hour where the demand exceeds the supply together with the regulating and contingency required reserve level.
- Capacity addition per updates from DOE Visayas Power Committed Project as of June 30, 2024:
 - Biliran Geothermal Plant Project (Phase 2) (6MW) - target date of commercial operation: January 2025
 - Mahanagdong Geothermal Brine Optimization Power Plant (28MW) - target date of commercial operation: September 2025
 - Bao Hydroelectric Power Project (2.0MW) - target date of commercial operation: July 2025
 - 70-MW Biomass Cogeneration Plant (30-MW Expansion Project) (30MW) - target date of commercial operation: May 2025
 - San Isidro Solar Power Project (226.842MW) - target date of commercial operation: June 2025
 - Kananga-Ormoc Solar Power Project (300MW) - target date of commercial operation: December 2025
 - Dagohoy Solar Power Project (20.622MW) - target date of commercial operation: February 2025
 - Nabas Wind Power Project (13.20MW) - target date of commercial operation: May 1, 2025
- Naga-Ormoc HVDC maintenance schedule is on October 23 - 29, 2025
- Lala-Dumanjug HVDC maintenance schedule is on July 23 - 29, 2025 for Pole 1, August 21 - 27, 2025 for Pole 2, and September 24 - 30, 2025 for Bipole



VISAYAS GRID 2025 Weekly Demand, Supply and Operating Margin Profile Evening Peak Scenario with 450 MW Import from Mindanao



2025	JANUARY TO JUNE 2025																											
	Dec 30	Jan 06	Jan 13	Jan 20	Jan 27	Feb 03	Feb 10	Feb 17	Feb 24	Mar 03	Mar 10	Mar 17	Mar 24	Mar 31	Apr 07	Apr 14	Apr 21	Apr 28	May 05	May 12	May 19	May 26	Jun 02	Jun 09	Jun 15	Jun 22	Jun 29	
	Jan 05	Jan 12	Jan 19	Jan 26	Feb 02	Feb 09	Feb 16	Feb 23	Mar 02	Mar 09	Mar 16	Mar 23	Mar 30	Apr 06	Apr 13	Apr 20	Apr 27	May 04	May 11	May 18	May 25	Jun 01	Jun 08	Jun 15	Jun 22	Jun 29		
Available Generating Capacity (MW)	2,892	2,774	2,741	2,587	2,561	2,681	2,674	2,622	2,569	2,586	2,544	2,427	2,633	2,882	2,882	2,873	2,882	2,856	2,802	2,802	2,802	2,802	2,806	2,806	2,806	2,806	2,806	
Thermal	1,321	1,321	1,218	1,049	1,049	1,152	1,152	1,152	1,152	1,157	1,054	1,054	1,136	1,321	1,321	1,321	1,321	1,321	1,321	1,321	1,321	1,321	1,321	1,321	1,321	1,321	1,321	
Geothermal	800	763	763	763	763	763	763	716	666	666	727	727	727	800	800	800	800	800	800	800	800	800	800	800	800	800	800	
Diesel	332	252	321	336	320	336	336	324	324	336	336	219	336	336	336	336	336	330	330	330	330	330	330	330	330	330	330	
Power Barges	52	52	52	52	52	52	45	52	45	45	45	45	52	52	52	52	52	52	52	52	52	52	52	52	52	52	52	
Hydro	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	63	72	73	73	73	73	73	73	73	73	73	73	
Biomass	267	267	267	267	267	267	267	267	267	267	267	267	267	267	267	267	267	267	214	214	214	214	208	208	208	208	208	
Solar	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
Wind	48	48	48	48	39	39	39	39	43	43	43	43	43	34	34	34	34	14	13	13	13	13	23	23	23	23	23	
BESS	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
System Peak Demand (MW)	2,291	2,177	2,190	2,176	2,125	2,178	2,152	2,319	2,319	2,360	2,468	2,478	2,526	2,537	2,537	2,645	2,757	2,716	2,874	2,858	2,868	2,650	2,664	2,663	2,539	2,606	2,606	
Operating Margin (MW)	601	597	551	411	436	503	522	303	250	226	76	-51	107	345	345	228	125	140	-72	-56	-66	152	142	143	267	200	200	
Stranded Capacity (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Net Operating Margin (MW)	601	597	551	411	436	503	522	303	250	226	76	0	107	345	345	228	125	140	0	0	0	152	142	143	267	200	200	
Req'd Regulating Reserve	92	87	88	87	85	87	86	93	93	94	99	99	101	101	101	106	110	109	115	114	115	106	107	107	102	104	104	
Req'd Contingency Reserve	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	
Req'd Dispatchable Reserve	169	169	169	150	150	150	150	150	150	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	
Available Import from Luzon (HVDC)	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	
Available Import from Mindanao (MVIP)	450	450	450	450	450	450	450	450	450	322	450	450	450	450	450	380	450	450	449	450	450	450	450	450	450	450	450	


- Peak Demand Forecast at 3,111 MW to occur in May 2025 based from the DOE Peak Demand Forecast 2020-2040.
- Preventive Maintenance of Power Plants considered.
- Embedded Generators considered.
- Evening Peak was considered in the outlook, hence, Solar Capacity not included.
- Capacity Factor for VRE Plants used: average of 17% for Solar and 22% for Wind (average of actual capacity for the previous year): Based on 24 hours
- The operating margin per week shown on the graph is based on the forecasted evening peak demand per week and its coincident available capacity.
- The Loss of Load Probability (LOLP) shown on the graph is derived with the consideration of capacity sharing among three regions and based on hourly projected peak demand. Hourly LOLP measures the probability that, during a specific hour, the electricity demand will exceed the available generation capacity.
- The Probability of Yellow and Red Levels shown on the graph are derived with the consideration of capacity sharing among three regions and based on daily projected peak demand. Daily Probability of Yellow and Red Levels measures the probability that, at any time during a particular day, there will be at least one hour where the demand exceeds the supply together with the regulating and contingency required reserve level.
- Capacity addition per updates from DOE Visayas Power Committed Project as of June 30, 2024:
 - 1.1 Biliran Geothermal Plant Project (Phase 2) (6MW) - target date of commercial operation: January 2025
 - 1.2 Mahanagdong Geothermal Brine Optimization Power Plant (28MW) - target date of commercial operation: September 2025
 - 1.3 Bao Hydroelectric Power Project (2.0MW) - target date of commercial operation: July 2025
 - 1.4 70-MW Biomass Cogeneration Plant (30-MW Expansion Project) (30MW) - target date of commercial operation: May 2025
 - 1.5 San Isidro Solar Power Project (226.842MW) - target date of commercial operation: June 2025
 - 1.6 Kananga-Ormoc Solar Power Project (300MW) - target date of commercial operation: December 2025
 - 1.7 Dagohoy Solar Power Project (20.622MW) - target date of commercial operation: February 2025
 - 1.8 Nabas Wind Power Project (13.20MW) - target date of commercial operation: May 1, 2025
- Naga-Ormoc HVDC maintenance schedule is on October 23 - 29, 2025
- Lala-Dumanjug HVDC maintenance schedule is on July 23 - 29, 2025 for Pole 1, August 21 - 27, 2025 for Pole 2, and September 24 - 30, 2025 for Bipole



VISAYAS GRID

2025 Weekly Demand, Supply and Operating Margin Profile

Evening Peak Scenario with 450 MW Import from Mindanao



2025	JULY TO DECEMBER 2025																											
	Jun 30	Jul 07	Jul 14	Jul 21	Jul 28	Aug 04	Aug 11	Aug 18	Aug 25	Sep 01	Sep 08	Sep 15	Sep 22	Sep 29	Oct 06	Oct 13	Oct 20	Oct 27	Nov 03	Nov 10	Nov 17	Nov 24	Dec 01	Dec 08	Dec 15	Dec 22		
	Jul 06	Jul 13	Jul 20	Jul 27	Aug 03	Aug 10	Aug 17	Aug 24	Aug 31	Sep 07	Sep 14	Sep 21	Sep 28	Oct 05	Oct 12	Oct 19	Oct 26	Nov 02	Nov 09	Nov 16	Nov 23	Nov 30	Dec 07	Dec 14	Dec 21	Dec 28		
Available Generating Capacity (MW)	2,690	2,709	2,670	2,691	2,680	2,686	2,699	2,684	2,610	2,705	2,685	2,671	2,690	2,769	2,652	2,644	2,683	2,629	2,723	2,751	2,704	2,601	2,620	2,732	2,745	2,859		
Thermal	1,239	1,239	1,239	1,239	1,239	1,239	1,239	1,239	1,239	1,239	1,239	1,239	1,239	1,321	1,186	1,186	1,186	1,186	1,321	1,321	1,321	1,218	1,218	1,218	1,218	1,321		
Geothermal	800	800	800	794	794	794	800	800	714	800	780	760	767	767	780	780	800	735	735	770	710	710	735	800	800	800		
Diesel	302	313	274	309	293	293	300	277	300	256	256	256	267	277	282	268	287	270	235	235	235	235	235	282	288	300		
Power Barges	45	45	45	45	38	52	52	52	52	46	46	52	52	46	46	52	52	52	46	39	52	52	46	46	52	52		
Hydro	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73		
Biomass	200	208	208	200	208	200	200	208	208	267	267	267	267	267	267	267	267	267	267	267	267	267	267	267	267	267		
Solar	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
Wind	31	31	31	31	35	35	35	35	25	25	25	25	25	19	19	19	19	47	47	47	47	47	47	47	47	47		
BESS	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
System Peak Demand (MW)	2,615	2,603	2,518	2,614	2,789	2,752	2,605	2,688	2,712	2,735	2,724	2,827	2,776	2,927	2,888	2,880	2,904	2,904	2,998	2,965	2,944	2,957	2,890	2,942	2,414	2,339		
Operating Margin (MW)	75	106	152	77	-109	-66	94	-4	-102	-30	-39	-156	-86	-158	-236	-236	-221	-275	-275	-214	-240	-356	-270	-210	331	520		
Stranded Capacity (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
Net Operating Margin (MW)	75	106	152	77	0	0	94	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	331	520		
Req'd Regulating Reserve	105	104	101	105	112	110	104	108	108	109	109	113	111	117	116	115	116	116	120	119	118	118	116	118	97	94		
Req'd Contingency Reserve	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169		
Req'd Dispatchable Reserve	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169		
Available Import from Luzon (HVDC)	250	250	250	250	250	204	58	250	250	250	250	250	250	250	250	250	0	250	250	250	250	250	250	250	250	250		
Available Import from Mindanao (MVIP)	450	450	450	225	450	430	450	225	450	356	388	293	0	334	450	399	280	436	311	351	450	450	450	450	450	450		


- Peak Demand Forecast at 3,111 MW to occur in May 2025 based from the DOE Peak Demand Forecast 2020-2040.
- Preventive Maintenance of Power Plants considered.
- Embedded Generators considered.
- Evening Peak was considered in the outlook, hence, Solar Capacity not included.
- Capacity Factor for VRE Plants used: average of 17% for Solar and 22% for Wind (average of actual capacity for the previous year): Based on 24 hours
- The operating margin per week shown on the graph is based on the forecasted evening peak demand per week and its coincident available capacity.
- The Loss of Load Probability (LOLP) shown on the graph is derived with the consideration of capacity sharing among three regions and based on hourly projected peak demand. Hourly LOLP measures the probability that, during a specific hour, the electricity demand will exceed the available generation capacity.
- The Probability of Yellow and Red Levels shown on the graph are derived with the consideration of capacity sharing among three regions and based on daily projected peak demand. Daily Probability of Yellow and Red Levels measures the probability that, at any time during a particular day, there will be at least one hour where the demand exceeds the supply together with the regulating and contingency required reserve level.
- Capacity addition per updates from DOE Visayas Power Committed Project as of June 30, 2024:
 - 1.1 Billiran Geothermal Plant Project (Phase 2) (6MW) - target date of commercial operation: January 2025
 - 1.2 Mahanagdong Geothermal Brine Optimization Power Plant (28MW) - target date of commercial operation: September 2025
 - 1.3 Bao Hydroelectric Power Project (2.0MW) - target date of commercial operation: July 2025
 - 1.4 70-MW Biomass Cogeneration Plant (30-MW Expansion Project) (30MW) - target date of commercial operation: May 2025
 - 1.5 San Isidro Solar Power Project (226.842MW) - target date of commercial operation: June 2025
 - 1.6 Kananga-Ormoc Solar Power Project (300MW) - target date of commercial operation: December 2025
 - 1.7 Dagohoy Solar Power Project (20.622MW) - target date of commercial operation: February 2025
 - 1.8 Nabas Wind Power Project (13.20MW) - target date of commercial operation: May 1, 2025
- Naga-Ormoc HVDC maintenance schedule is on October 23 - 29, 2025
- Lala-Dumanjug HVDC maintenance schedule is on July 23 - 29, 2025 for Pole 1, August 21 - 27, 2025 for Pole 2, and September 24 - 30, 2025 for Bipole



MINDANAO GRID

2025 Weekly Demand, Supply and Operating Margin Profile

450 MW Export to Visayas




2025	JANUARY TO JUNE 2025																									
	Dec 30	Jan 06	Jan 13	Jan 20	Jan 27	Feb 03	Feb 10	Feb 17	Feb 24	Mar 03	Mar 10	Mar 17	Mar 24	Mar 31	Apr 07	Apr 14	Apr 21	Apr 28	May 05	May 12	May 19	May 26	Jun 02	Jun 09	Jun 16	Jun 23
	Jan 05	Jan 12	Jan 19	Jan 26	Feb 02	Feb 09	Feb 16	Feb 23	Mar 02	Mar 09	Mar 16	Mar 23	Mar 30	Apr 06	Apr 13	Apr 20	Apr 27	May 04	May 11	May 18	May 25	Jun 01	Jun 08	Jun 15	Jun 22	Jun 29
Available Generating Capacity (MW)	3,466	3,451	3,308	3,285	3,153	3,316	3,189	3,201	3,267	3,069	2,930	3,197	3,357	3,313	3,337	3,324	3,357	3,338	3,335	3,303	3,350	3,312	3,397	3,409	3,411	3,439
Coal	2,043	2,043	1,938	1,938	1,803	1,908	1,803	1,938	1,938	1,714	1,614	1,919	2,043	2,043	2,043	2,043	2,043	2,043	2,043	2,043	2,043	2,043	2,043	2,043	2,043	2,043
Geothermal	102	102	54	54	54	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102
Hydro	430	430	430	410	410	430	400	325	365	364	324	314	324	262	307	292	307	292	292	276	301	272	346	360	360	390
Diesel	359	359	359	359	359	359	359	311	359	359	359	359	359	359	359	359	359	359	359	359	359	359	359	359	359	359
Renewable	269	256	264	261	264	264	269	270	247	267	267	240	266	284	263	265	283	279	276	260	282	273	284	282	284	282
BESS	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Embedded	264	261	264	264	264	253	256	256	256	264	264	264	264	264	264	264	264	264	264	264	264	264	264	264	264	264
System Peak Demand (MW)	2,338	2,246	2,385	2,375	2,437	2,443	2,327	2,461	2,461	2,521	2,440	2,482	2,526	2,510	2,667	2,722	2,673	2,542	2,753	2,710	2,649	2,660	2,575	2,579	2,572	2,582
Operating Margin (MW)	1,128	1,205	924	911	716	873	862	740	806	549	489	715	831	803	670	602	684	796	581	593	701	651	822	829	839	857
Net of MVIP Export (MW)	678	755	474	461	278	435	424	302	368	239	236	277	393	365	245	247	246	358	248	246	263	244	393	400	409	427
Req'd Regulating Reserve	94	90	95	95	97	98	93	98	98	101	98	99	101	100	107	109	107	102	110	108	106	106	103	103	103	103
Req'd Contingency Reserve	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138
Req'd Dispatchable Reserve	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138
MVIP Export (MW)	450	450	450	450	450	450	450	450	450	322	265	450	450	450	438	367	450	450	345	359	450	427	450	450	450	450

- Peak Demand Forecast at 2,789 MW to occur in December 2025 based from the DOE Peak Demand Forecast 2020-2040
- Preventive Maintenance of Power Plants considered.
- Embedded Generators considered.
- Capacity Factor for VRE Plants used: 13-22% (average of actual capacity for previous year): Based on 24 hours
- The operating margin per week shown on the graph is based on the forecasted peak demand per week and its coincident available capacity.
- The Loss of Load Probability (LOLP) shown on the graph is derived with the consideration of capacity sharing among three regions and based on hourly projected peak demand. Hourly LOLP measures the probability that, during a specific hour, the electricity demand will exceed the available generation capacity.
- The Probability of Yellow and Red Levels shown on the graph are derived with the consideration of capacity sharing among three regions and based on daily projected peak demand. Daily Probability of Yellow and Red Levels measures the probability that, at any time during a particular day, there will be at least one hour where the demand exceeds the supply together with the regulating and contingency required reserve level.
- Capacity addition per updates from DOE Mindanao Power Committed Project as of June 30, 2024:
 - 8.1 Mangima Hydroelectric Power Project (12MW) - target date of commercial operation: February 2025
 - 8.2 Sangali Diesel Power Plant Phase 1 (28MW) - target date of commercial operation: July 2025
 - 8.3 Sangali Diesel Power Plant Phase 2 (28MW) - target date of commercial operation: July 2025
 - 8.4 Maladugao River (Upper Cascade) Hydroelectric Power Project (8.4MW) - target date of commercial operation: June 2025
 - 8.5 Malitbog Hydroelectric Power Project (3.7MW) - target date of commercial operation: November 2025
 - 8.6 Silo-o Hydroelectric Power Project (3.7MW) - target date of commercial operation: November 2025
 - 8.7 Mat-i 1 Hydroelectric Power Project (4.85MW) - target date of commercial operation: November 2025
 - 8.8 Clarin Hydroelectric Power Project (6.9MW) - target date of commercial operation: November 2025
 - 8.9 General Santos Solar Power Project (120MW) - target date of commercial operation: December 2025
 - 8.10 Butuan City 1 Solar Power Project (8MW) - target date of commercial operation: December 2025
- Lala-Dumanjug HVDC maintenance schedule is on July 23 - 29, 2025 for Pole 1, August 21 - 27, 2025 for Pole 2, and September 24 - 30, 2025 for Bipole



MINDANAO GRID 2025 Weekly Demand, Supply and Operating Margin Profile 450 MW Export to Visayas




2025	JULY TO DECEMBER 2025																									
	Jun 30	Jul 07	Jul 14	Jul 21	Jul 28	Aug 04	Aug 11	Aug 18	Aug 25	Sep 01	Sep 08	Sep 15	Sep 22	Sep 29	Oct 06	Oct 13	Oct 20	Oct 27	Nov 03	Nov 10	Nov 17	Nov 24	Dec 01	Dec 08	Dec 15	Dec 22
	Jul 06	Jul 13	Jul 20	Jul 27	Aug 03	Aug 10	Aug 17	Aug 24	Aug 31	Sep 07	Sep 14	Sep 21	Sep 28	Oct 05	Oct 12	Oct 19	Oct 26	Nov 02	Nov 09	Nov 16	Nov 23	Nov 30	Dec 07	Dec 14	Dec 21	Dec 28
Available Generating Capacity (MW)	3,455	3,305	3,179	3,269	3,267	3,165	3,121	3,305	3,210	3,130	3,119	3,013	3,160	3,300	3,269	3,259	3,109	3,278	3,186	3,176	3,307	3,270	3,277	3,276	3,418	3,483
Coal	1,943	1,808	1,708	1,808	1,808	1,784	1,784	1,919	1,781	1,781	1,781	1,643	1,767	1,905	1,919	1,899	1,764	1,908	1,808	1,808	1,943	1,908	1,908	1,908	2,043	2,043
Geothermal	102	102	102	102	102	102	102	98	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102
Hydro	509	509	479	469	469	429	385	389	429	367	357	387	387	402	356	366	351	377	392	392	402	416	391	416	397	462
Diesel	359	359	359	359	359	311	311	359	359	359	359	359	359	359	359	359	359	359	359	359	359	352	352	352	352	352
Renewable	282	268	268	268	268	282	282	282	283	257	257	258	282	269	269	269	269	269	269	260	245	247	269	243	269	269
BESS	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Embedded	261	260	264	264	261	257	257	257	257	264	264	264	264	264	264	264	264	264	256	256	256	246	256	256	256	256
System Peak Demand (MW)	2,625	2,552	2,594	2,600	2,701	2,662	2,486	2,538	2,595	2,625	2,534	2,515	2,654	2,739	2,620	2,698	2,674	2,620	2,713	2,736	2,718	2,738	2,726	2,789	2,628	2,451
Operating Margin (MW)	830	753	586	669	566	503	635	767	615	505	586	498	506	562	649	561	435	658	473	440	588	532	551	487	789	1,032
Net of MVIP Export (MW)	456	379	242	521	418	244	262	618	467	243	239	239	582	638	275	246	245	304	247	247	247	248	247	250	463	706
Req'd Regulating Reserve	105	102	104	104	108	106	99	102	104	105	101	101	106	110	105	108	107	105	109	109	109	110	109	112	105	98
Req'd Contingency Reserve	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138
Req'd Dispatchable Reserve	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138
MVIP Export (MW)	450	450	420	225	225	335	450	225	225	338	423	336	0	0	450	391	266	450	322	288	437	380	427	361	450	450

- Peak Demand Forecast at 2,789 MW to occur in December 2025 based on the DOE Peak Demand Forecast 2020-2040
- Preventive Maintenance of Power Plants considered.
- Embedded Generators considered.
- Capacity Factor for VRE Plants used: 13-22% (average of actual capacity for previous year): Based on 24 hours
- The operating margin per week shown on the graph is based on the forecasted peak demand per week and its coincident available capacity.
- The Loss of Load Probability (LOLP) shown on the graph is derived with the consideration of capacity sharing among three regions and based on hourly projected peak demand. Hourly LOLP measures the probability that, during a specific hour, the electricity demand will exceed the available generation capacity.
- The Probability of Yellow and Red Levels shown on the graph are derived with the consideration of capacity sharing among three regions and based on daily projected peak demand. Daily Probability of Yellow and Red Levels measures the probability that, at any time during a particular day, there will be at least one hour where the demand exceeds the supply together with the regulating and contingency required reserve level.
- Capacity addition per updates from DOE Mindanao Power Committed Project as of June 30, 2024:
 - Mangima Hydroelectric Power Project (12MW) - target date of commercial operation: February 2025
 - Sangali Diesel Power Plant Phase 1 (28MW) - target date of commercial operation: July 2025
 - Sangali Diesel Power Plant Phase 2 (28MW) - target date of commercial operation: July 2025
 - Maladugao River (Upper Cascade) Hydroelectric Power Project (8.4MW) - target date of commercial operation: June 2025
 - Malitbog Hydroelectric Power Project (3.7MW) - target date of commercial operation: November 2025
 - Silo-o Hydroelectric Power Project (3.7MW) - target date of commercial operation: November 2025
 - Mat-i 1 Hydroelectric Power Project (4.85MW) - target date of commercial operation: November 2025
 - Clarín Hydroelectric Power Project (6.9MW) - target date of commercial operation: November 2025
 - General Santos Solar Power Project (120MW) - target date of commercial operation: December 2025
 - Butuan City 1 Solar Power Project (8MW) - target date of commercial operation: December 2025
- Lala-Dumanjug HVDC maintenance schedule is on July 23 - 29, 2025 for Pole 1, August 21 - 27, 2025 for Pole 2, and September 24 - 30, 2025 for Bipole

LUZON GRID


2026 Weekly Demand, Supply and Operating Margin Profile



2026	JANUARY TO JUNE 2026																											
	Dec 29	Jan 05	Jan 12	Jan 19	Jan 26	Feb 02	Feb 09	Feb 16	Feb 23	Mar 02	Mar 09	Mar 16	Mar 23	Mar 30	Apr 06	Apr 13	Apr 20	Apr 27	May 04	May 11	May 18	May 25	Jun 01	Jun 08	Jun 15	Jun 22		
	Jan 04	Jan 11	Jan 18	Jan 25	Feb 01	Feb 08	Feb 15	Feb 22	Mar 01	Mar 08	Mar 15	Mar 22	Mar 29	Apr 05	Apr 12	Apr 19	Apr 26	May 03	May 10	May 17	May 24	May 31	Jun 07	Jun 14	Jun 21	Jun 28		
Available Generating Capacity (MW)	17,128	17,852	16,805	16,829	17,037	17,061	17,257	16,781	16,827	17,224	17,277	17,047	18,253	18,125	18,069	17,833	18,114	17,968	17,802	17,831	17,633	17,827	17,697	17,646	17,764	17,988		
Thermal	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
Coal	8,288	8,288	8,018	7,702	7,852	8,239	8,359	7,814	7,814	7,964	7,964	7,964	9,098	9,098	9,098	9,098	9,098	9,098	9,098	9,098	9,098	9,098	9,098	9,098	9,098	9,098		
Gas Turbine/Diesel	746	746	746	746	746	746	746	746	689	624	687	746	746	746	746	746	746	746	746	746	746	746	746	746	746	746		
Combined Cycle/NatGas	4,460	5,136	4,871	4,871	4,871	4,871	4,871	4,871	4,871	5,136	5,136	5,050	5,093	5,136	5,136	5,136	5,136	5,136	5,136	5,136	5,136	5,136	5,136	5,136	5,136	5,136		
Geothermal	487	487	487	487	487	467	455	467	467	487	467	467	467	487	487	481	481	481	487	487	400	400	487	465	487	487		
HVDC	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
Wind Farm	411	299	211	258	352	305	129	276	287	170	264	111	123	141	299	100	94	41	100	47	53	94	70	41	41	41		
Solar	416	576	512	480	448	672	576	544	608	672	608	640	640	640	576	544	608	640	640	544	544	608	544	544	640	576		
BESS	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
Biomass	142	142	142	142	142	148	148	148	148	154	136	136	154	154	150	150	154	154	154	154	154	154	154	154	154	154		
Hydro	2,179	2,179	1,819	2,144	2,140	1,614	1,974	1,916	1,943	2,017	2,016	1,933	1,932	1,723	1,577	1,579	1,797	1,673	1,474	1,523	1,503	1,591	1,462	1,462	1,462	1,750		
System Peak Demand (MW)	11,888	12,754	12,968	12,916	13,187	13,253	13,361	13,524	13,727	13,949	14,160	14,341	14,489	14,644	14,793	15,120	15,400	15,595	15,683	15,677	15,625	15,545	15,489	15,405	15,316	15,226		
Operating Margin (MW)	4,991	4,849	3,587	3,664	3,600	3,558	3,646	3,007	2,849	3,025	2,867	2,456	3,514	3,230	3,026	2,463	2,464	2,124	1,869	1,904	1,758	2,032	1,958	1,990	2,198	2,512		
Req'd Regulating Reserve	476	510	519	517	527	530	534	541	549	558	566	574	580	586	592	605	616	624	627	627	625	622	620	616	613	609		
Req'd Contingency Reserve	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668		
Req'd Dispatchable Reserve	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668		
HVDC Export (MW)	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250		

- Peak Demand Forecast at 15,683 MW to occur in May 2026 based from the DOE Peak Demand Forecast 2020-2040
- Preventive Maintenance of Power Plants considered.
- Embedded Generators considered.
- Capacity Factor for VRE Plants used: average of 16% for Solar and 30% for Wind (average of actual capacity for 3 years: 2021 to 2023): Based on 24 hours
- Consideration of additional capacities of new VRE Plants
- The operating margin per week shown on the graph is based on the forecasted peak demand per week and its coincident available capacity.
- The Loss of Load Probability (LOLP) shown on the graph is derived with the consideration of capacity sharing among three regions and based on hourly projected peak demand. Hourly LOLP measures the probability that, during a specific
- The Probability of Yellow and Red Levels shown on the graph are derived with the consideration of capacity sharing among three regions and based on daily projected peak demand. Daily Probability of Yellow and Red Levels measures the
- Capacity addition per updates from DOE Luzon Power Committed Project as of June 30, 2024:
 - Masinloc Power Plant - Unit 5 (350 MW) - target date of commercial operation: April 2026
 - Pasquin-Burgos 100MW Solar Power Plant (49 MW) - target date of commercial operation: June 2026
 - Sapang Balen Solar 2 Power Project (246.604MW) - target date of commercial operation: December 2026
 - Ixus Bugallon Solar Power Project (274.735MW) - target date of commercial operation: December 2026
 - San Pablo Solar Power Project Phase 2 (79.040MW) - target date of commercial operation: December 2026
 - Santa Rosa Nueva Ecija 3 Solar Power Project (20MW) - target date of commercial operation: December 2026
 - Linglingay Solar Power Project (70.14MW) - target date of commercial operation: December 2026
 - NKS One Floating Solar Power Project (90MW) - target date of commercial operation: December 2026
 - YH Pangasinan Norte Solar Power Project (6.90MW) - target date of commercial operation: December 2026
 - Opus Solar Power Project (149.950MW) - target date of commercial operation: December 2026
- Naga-Ormoc HVDC maintenance schedule is on October 23 - 29, 2026.
 - Quezon Wind Power Project (239.990MW) - target date of commercial operation: December 15, 2026
 - Camarines Sur Wind Power Project (49.999MW) - target date of commercial operation: December 23, 2026
 - Isla Mind Power Project (230MW) - target date of commercial operation: December 24, 2026
 - Pangasinan CW 2 Wind Power Project (80MW) - target date of commercial operation: December 26, 2026
 - Bataan-Zambales CW Wind Power Project (100MW) - target date of commercial operation: December 26, 2026
 - Camarines Sur CW Wind Power Project (30MW) - target date of commercial operation: December 26, 2026

LUZON GRID 2026 Weekly Demand, Supply and Operating Margin Profile



2026	JULY TO DECEMBER 2026																											
	Jun 29	Jul 06	Jul 13	Jul 20	Jul 27	Aug 03	Aug 10	Aug 17	Aug 24	Aug 31	Sep 07	Sep 14	Sep 21	Sep 28	Oct 05	Oct 12	Oct 19	Oct 26	Nov 02	Nov 09	Nov 16	Nov 23	Nov 30	Dec 07	Dec 14	Dec 21	Dec 28	
	Jul 05	Jul 12	Jul 19	Jul 26	Aug 02	Aug 09	Aug 16	Aug 23	Aug 30	Sep 06	Sep 13	Sep 20	Sep 27	Sep 24	Oct 01	Oct 18	Oct 25	Nov 01	Nov 08	Nov 15	Nov 22	Nov 29	Dec 06	Dec 13	Dec 20	Dec 27	Jan 03	
Available Generating Capacity (MW)	18,080	17,785	17,503	17,525	17,380	17,665	17,916	17,473	17,434	16,894	16,789	16,883	16,974	16,207	16,872	17,106	17,074	17,826	17,367	16,629	16,499	16,910	17,187	17,010	16,784	16,785	17,745	
Thermal	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
Coal	8,948	8,566	8,416	8,416	8,295	8,677	8,670	8,588	8,251	7,801	7,485	7,717	7,872	7,206	7,816	7,816	7,816	8,451	8,206	7,388	7,388	7,628	7,924	7,924	7,774	7,774	8,720	
Gas Turbine/Diesel	734	674	672	693	742	742	736	740	740	740	736	742	738	638	746	740	740	729	735	746	746	746	596	724	718	746	746	
Combined Cycle/NatGas	5,136	5,136	5,136	5,136	5,136	4,820	5,076	4,818	5,076	5,076	5,076	4,990	4,870	4,870	4,871	5,136	5,136	5,046	5,046	5,046	5,046	5,136	4,812	4,736	4,736	4,671	4,460	
Geothermal	487	447	387	387	387	347	427	427	427	427	417	447	487	487	447	447	447	447	487	487	400	487	487	487	487	487	487	
HVDC	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
Wind Farm	29	35	29	94	106	276	76	6	76	141	111	23	106	35	88	94	158	323	182	311	305	287	422	258	188	258	488	
Solar	512	544	480	416	320	416	544	512	480	320	576	576	512	578	512	480	384	448	608	544	480	448	576	512	512	480	571	
BESS	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
Biomass	154	154	154	154	154	141	141	141	141	146	146	146	146	154	154	154	154	154	154	136	154	154	154	154	154	154	95	
Hydro	2,080	2,230	2,229	2,230	2,241	2,246	2,246	2,241	2,243	2,243	2,241	2,242	2,243	2,239	2,239	2,239	2,239	2,228	1,950	1,972	1,981	2,024	2,216	2,216	2,216	2,216	2,179	
System Peak Demand (MW)	15,128	15,008	14,876	14,776	14,749	14,793	14,857	14,887	14,879	14,873	14,907	14,975	15,036	15,054	15,029	14,986	14,944	14,908	14,883	14,871	14,865	14,832	14,739	14,584	14,409	14,092	12,170	
Operating Margin (MW)	2,702	2,528	2,377	2,499	2,381	2,621	2,809	2,336	2,305	1,771	1,632	1,657	1,688	912	1,593	1,870	2,131	2,917	2,234	1,508	1,384	1,827	2,197	2,176	2,125	2,444	5,325	
Req'd Regulating Reserve	605	600	595	591	590	592	594	595	595	595	596	599	601	602	601	599	598	596	595	595	595	593	590	583	576	564	487	
Req'd Contingency Reserve	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	670	
Req'd Dispatchable Reserve	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	647	647	647	668	668	668	670	
HVDC Export (MW)	250	250	250	250	250	250	250	250	250	250	250	250	250	250	241	250	250	0	0	250	250	250	250	250	250	250	250	

1. Peak Demand Forecast at 15,683 MW to occur in May 2026 based from the DOE Peak Demand Forecast 2020-2040

2. Preventive Maintenance of Power Plants considered.

3. Embedded Generators considered.

4. Capacity Factor for VRE Plants used: average of 16% for Solar and 30% for Wind (average of actual capacity for 3 years: 2021 to 2023): Based on 24 hours

5. Consideration of additional capacities of new VRE Plants

6. The operating margin per week shown on the graph is based on the forecasted peak demand per week and its coincident available capacity.

7. The Loss of Load Probability (LOLP) shown on the graph is derived with the consideration of capacity sharing among three regions and based on hourly projected peak demand. Hourly LOLP measures the probability that, during a specific hour, the electricity demand will

8. The Probability of Yellow and Red Levels shown on the graph are derived with the consideration of capacity sharing among three regions and based on daily projected peak demand. Daily Probability of Yellow and Red Levels measures the probability that, at any time during

9. Capacity addition per updates from DOE Luzon Power Committed Project as of June 30, 2024:

9.1 Masinloc Power Plant - Unit 5 (350 MW) - target date of commercial operation: April 2026

9.2 Pasuquin-Burgos 100MW Solar Power Project (49 MW) - target date of commercial operation: June 2026

9.3 Sapang Balen Solar 2 Power Project (246.604MW) - target date of commercial operation: December 2026

9.4 Ixus Bugallon Solar Power Project (274.735MW) - target date of commercial operation: December 2026

9.5 San Pablo Solar Power Project Phase 2 (79.040MW) - target date of commercial operation: December 2026

9.6 Santa Rosa Nueva Ecija 3 Solar Power Project (20MW) - target date of commercial operation: December 2026

9.7 Linglingay Solar Power Project (70.14MW) - target date of commercial operation: December 2026

9.8 NKS One Floating Solar Power Project (90MW) - target date of commercial operation: December 2026

9.9 YH Pangasinan Norte Solar Power Project (6.90MW) - target date of commercial operation: December 2026

9.10 Opus Solar Power Project (149.950MW) - target date of commercial operation: December 2026

10. Naga-Ormoc HVDC maintenance schedule is on October 23 - 29, 2026.

9.11 Quezon Wind Power Project (239.990MW) - target date of commercial operation: December 15, 2026

9.12 Camarines Sur Wind Power Project (49.999MW) - target date of commercial operation: December 23, 2026

9.13 Isla Wind Power Project (230MW) - target date of commercial operation: December 24, 2026

9.14 Pangasinan CW 2 Wind Power Project (80MW) - target date of commercial operation: December 26, 2026

9.15 Bataan-Zambales CW Wind Power Project (100MW) - target date of commercial operation: December 26, 2026


9.16 Camarines Sur CW Wind Power Project (30MW) - target date of commercial operation: December 26, 2026



VISAYAS GRID

2026 Weekly Demand, Supply and Operating Margin Profile

Afternoon Peak Scenario with 450 MW Import from Mindanao



2026	JANUARY TO JUNE 2026																											
	Dec 29	Jan 05	Jan 12	Jan 19	Jan 26	Feb 02	Feb 09	Feb 16	Feb 23	Mar 02	Mar 09	Mar 16	Mar 23	Mar 30	Apr 06	Apr 13	Apr 20	Apr 27	May 04	May 11	May 18	May 25	Jun 01	Jun 08	Jun 15	Jun 22		
	Jan 04	Jan 11	Jan 18	Jan 25	Feb 01	Feb 08	Feb 15	Feb 22	Mar 01	Mar 08	Mar 15	Mar 22	Mar 29	Apr 05	Apr 12	Apr 19	Apr 26	May 03	May 10	May 17	May 24	May 31	Jun 07	Jun 14	Jun 21	Jun 28		
Available Generating Capacity (MW)	2,897	2,753	2,423	2,568	2,784	3,051	2,847	2,781	2,878	2,796	2,693	2,723	2,950	3,046	3,149	3,149	3,140	3,071	3,053	3,053	3,053	3,037	3,032	3,032	3,005	3,032		
Thermal	1,171	986	817	817	1,049	1,321	1,152	1,070	1,070	988	885	967	1,136	1,218	1,321	1,321	1,321	1,321	1,321	1,321	1,321	1,321	1,321	1,321	1,321	1,321		
Geothermal	834	834	719	834	778	778	758	775	814	814	814	834	834	834	834	834	834	834	834	834	834	834	834	834	834	834		
Diesel	300	300	254	285	300	295	280	280	300	300	300	235	300	300	300	300	300	300	300	300	300	300	300	300	288	300		
Power Barges	52	52	52	52	52	52	52	52	52	52	52	45	38	52	52	52	52	52	52	52	52	52	52	52	52	52		
Hydro	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	72	72	72	73	73	73	73	73		
Biomass	226	267	267	267	267	267	267	267	267	267	267	267	267	267	267	267	267	232	214	214	214	214	208	208	208	208		
Solar	193	193	193	193	227	227	227	227	260	260	260	260	260	270	270	270	270	247	247	247	247	222	222	222	207	222		
Wind	48	48	48	48	39	39	39	39	43	43	43	43	43	34	34	34	25	13	13	13	13	22	23	23	23	23		
BESS	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
System Peak Demand (MW)	2,414	2,339	2,486	2,461	2,398	2,467	2,434	2,794	2,794	2,708	2,860	2,975	3,006	3,044	3,044	3,200	3,273	3,228	3,324	3,338	3,340	3,165	3,167	3,167	3,026	3,069		
Operating Margin (MW)	483	414	-63	107	386	584	413	-13	84	88	-167	-252	-56	2	105	-51	-133	-157	-271	-285	-287	-128	-135	-135	-21	-37		
Stranded Capacity (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
Net Operating Margin (MW)	483	414	0	107	386	584	413	0	84	88	0	0	0	0	2	105	0	0	0	0	0	0	0	0	0	0		
Req'd Regulating Reserve	97	94	99	98	96	99	97	112	112	108	114	119	120	122	122	128	131	129	133	134	134	127	127	127	121	123		
Req'd Contingency Reserve	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169		
Req'd Dispatchable Reserve	169	169	135	135	150	169	150	150	150	150	150	150	169	169	169	169	169	169	169	169	169	169	169	169	169	169		
Available Import from Luzon (HVDC)	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250		
Available Import from Mindanao (MVIP)	450	450	450	450	395	450	450	371	450	291	450	381	136	450	450	450	450	450	442	450	450	450	450	450	450	450		


- Peak Demand Forecast at 3,340 MW to occur in May 2026 based from the DOE Peak Demand Forecast 2020-2040.
- Preventive Maintenance of Power Plants considered.
- Embedded Generators considered.
- Capacity Factor for VRE Plants used: average of 17% for Solar and 22% for Wind (average of actual capacity for the previous year): Based on 24 hours
- The operating margin per week shown on the graph is based on the forecasted afternoon peak demand per week and its coincident available capacity.
- The Loss of Load Probability (LOLP) shown on the graph is derived with the consideration of capacity sharing among three regions and based on hourly projected peak demand. Hourly LOLP measures the probability that,
- The Probability of Yellow and Red Levels shown on the graph are derived with the consideration of capacity sharing among three regions and based on daily projected peak demand. Daily Probability of Yellow and Red
- Capacity addition per updates from DOE Visayas Power Committed Project as of June 30, 2024:
 - Ajuy 1 Solar Power Plant Project (14MW) - target date of commercial operation: January 2026
 - Luca Solar Power Project (80MW) - target date of commercial operation: September 2026
 - Silay 2b Solar Power Project (20MW) - target date of commercial operation: December 2026
 - Toledo Solar Power Project (49MW) - target date of commercial operation: December 2026
 - Silay 2a Solar Power Project (30MW) - target date of commercial operation: December 2026
 - Silay Solar Power Project (20MW) - target date of commercial operation: December 2026
 - Bago Wind Power Project (150MW) - target date of commercial operation: December 26, 2026
 - Iloilo CW 1 Wind Power Project (152MW) - target date of commercial operation: December 26, 2026
 - Gemini Wind Power Project (200MW) - target date of commercial operation: December 15, 2026
- Naga-Ormoc HVDC maintenance schedule is on October 23 - 29, 2026.
- Lala-Dumanjug HVDC maintenance schedule is on July 23 - 29, 2026 for Pole 1, August 20 - 26, 2026 for Pole 2, and September 23 - 29, 2026 for Bipole



VISAYAS GRID

2026 Weekly Demand, Supply and Operating Margin Profile

Afternoon Peak Scenario with 450 MW Import from Mindanao




2026	JULY TO DECEMBER 2026																													
	Jun 29	Jul 06	Jul 13	Jul 20	Jul 27	Aug 03	Aug 10	Aug 17	Aug 24	Aug 31	Sep 07	Sep 14	Sep 21	Sep 28	Oct 05	Oct 12	Oct 19	Oct 26	Nov 02	Nov 09	Nov 16	Nov 23	Nov 30	Dec 07	Dec 14	Dec 21	Dec 27	Jan 03		
	Jul 05	Jul 12	Jul 19	Jul 26	Aug 02	Aug 09	Aug 16	Aug 23	Aug 30	Sep 06	Sep 13	Sep 20	Sep 27	Oct 04	Oct 11	Oct 18	Oct 25	Nov 01	Nov 08	Nov 15	Nov 22	Nov 29	Dec 06	Dec 13	Dec 20	Dec 27	Jan 03			
Available Generating Capacity (MW)	2,790	2,741	2,814	2,995	3,019	2,965	2,958	2,832	2,879	2,938	2,867	2,891	3,032	3,075	3,028	2,985	2,954	3,102	3,092	3,060	2,977	3,072	2,948	2,942	2,948	3,094	3,100			
Thermal	1,157	1,157	1,157	1,321	1,321	1,239	1,239	1,186	1,186	1,186	1,186	1,321	1,321	1,321	1,321	1,321	1,321	1,321	1,321	1,321	1,321	1,321	1,218	1,218	1,218	1,321	1,321			
Geothermal	797	747	797	834	834	834	834	769	834	834	769	704	834	834	798	834	804	834	834	798	726	798	798	798	798	834	834			
Diesel	276	276	276	280	280	288	282	280	273	282	276	224	235	277	272	201	207	288	277	288	277	293	293	287	293	300	300			
Power Barges	45	45	52	52	52	52	52	52	52	46	46	52	52	46	46	46	46	46	46	39	39	46	46	46	46	46	52			
Hydro	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73			
Biomass	200	208	208	200	208	208	208	208	208	267	267	267	267	267	267	267	267	267	267	267	267	267	267	267	267	267	267			
Solar	221	205	221	205	216	236	236	229	228	226	226	226	226	238	233	225	218	227	227	227	227	227	206	206	206	206	206			
Wind	22	31	31	31	35	35	35	35	25	25	25	25	25	19	19	19	19	47	47	47	47	47	47	47	47	47	47			
BESS	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
System Peak Demand (MW)	3,122	3,062	3,012	3,118	3,209	3,210	3,125	3,181	3,219	3,199	3,260	3,248	3,155	3,273	3,203	3,169	3,146	3,146	3,257	3,244	3,210	3,181	3,161	3,139	2,553	2,386	2,208			
Operating Margin (MW)	-332	-321	-198	-123	-190	-245	-167	-349	-340	-261	-393	-357	-123	-198	-175	-184	-192	-44	-165	-184	-233	-109	-213	-197	395	708	892			
Stranded Capacity (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0			
Net Operating Margin (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	395	708	892			
Req'd Regulating Reserve	125	122	120	125	128	128	125	127	129	128	130	130	126	131	128	127	126	126	130	130	128	127	126	126	102	95	88			
Req'd Contingency Reserve	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169			
Req'd Dispatchable Reserve	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169			
Available Import from Luzon (HVDC)	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	0	250	250	250	250	250	250	250	250	250	250			
Available Import from Mindanao (MVIP)	450	450	450	225	450	450	399	225	450	314	348	350	0	139	322	223	110	312	357	213	256	303	375	241	450	450	450			

- Peak Demand Forecast at 3,340 MW to occur in May 2026 based from the DOE Peak Demand Forecast 2020-2040.
- Preventive Maintenance of Power Plants considered.
- Embedded Generators considered.
- Capacity Factor for VRE Plants used: average of 17% for Solar and 22% for Wind (average of actual capacity for the previous year): Based on 24 hours
- The operating margin per week shown on the graph is based on the forecasted afternoon peak demand per week and its coincident available capacity.
- The Loss of Load Probability (LOLP) shown on the graph is derived with the consideration of capacity sharing among three regions and based on hourly projected peak demand. Hourly LOLP measures the probability
- The Probability of Yellow and Red Levels shown on the graph are derived with the consideration of capacity sharing among three regions and based on daily projected peak demand. Daily Probability of Yellow and Red
- Capacity addition per updates from DOE Visayas Power Committed Project as of June 30, 2024:
 - Ajuy 1 Solar Power Plant Project (14MW) - target date of commercial operation: January 2026
 - Luca Solar Power Project (80MW) - target date of commercial operation: September 2026
 - Silay 2b Solar Power Project (20MW) - target date of commercial operation: December 2026
 - Toledo Solar Power Project (49MW) - target date of commercial operation: December 2026
 - Silay 2a Solar Power Project (30MW) - target date of commercial operation: December 2026
 - Silay Solar Power Project (20MW) - target date of commercial operation: December 2026
 - Bago Wind Power Project (150MW) - target date of commercial operation: December 26, 2026
 - Iloilo CW 1 Wind Power Project (152MW) - target date of commercial operation: December 26, 2026
 - Gemini Wind Power Project (200MW) - target date of commercial operation: December 15, 2026
- Naga-Ormoc HVDC maintenance schedule is on October 23 - 29, 2026.
- Lala-Dumanjug HVDC maintenance schedule is on July 23 - 29, 2026 for Pole 1, August 20 - 26, 2026 for Pole 2, and September 23 - 29, 2026 for Bipole



VISAYAS GRID 2026 Weekly Demand, Supply and Operating Margin Profile Evening Peak Scenario with 450 MW Import from Mindanao




2026	JANUARY TO JUNE 2026																											
	Dec 29	Jan 05	Jan 12	Jan 19	Jan 26	Feb 02	Feb 09	Feb 16	Feb 23	Mar 02	Mar 09	Mar 16	Mar 23	Mar 30	Apr 06	Apr 13	Apr 20	Apr 27	May 04	May 11	May 18	May 25	Jun 01	Jun 08	Jun 15	Jun 22		
	Jan 04	Jan 11	Jan 18	Jan 25	Feb 01	Feb 08	Feb 15	Feb 22	Mar 01	Mar 08	Mar 15	Mar 22	Mar 29	Apr 05	Apr 12	Apr 19	Apr 26	May 03	May 10	May 17	May 24	May 31	Jun 07	Jun 14	Jun 21	Jun 28		
Available Generating Capacity (MW)	2,703	2,559	2,230	2,375	2,557	2,683	2,670	2,554	2,618	2,536	2,433	2,463	2,690	2,777	2,880	2,862	2,880	2,860	2,806	2,806	2,806	2,806	2,810	2,810	2,798	2,810		
Thermal	1,171	986	817	817	1,049	1,218	1,152	1,070	1,070	988	885	967	1,136	1,218	1,321	1,321	1,321	1,321	1,321	1,321	1,321	1,321	1,321	1,321	1,321	1,321		
Geothermal	834	834	719	834	778	741	808	775	814	814	814	834	834	834	834	834	834	834	834	834	834	834	834	834	834	834		
Diesel	300	300	254	285	300	295	280	280	300	300	300	235	300	300	300	300	300	300	300	300	300	300	300	300	288	300		
Power Barges	52	52	52	52	52	52	52	52	52	52	52	45	38	52	52	52	52	52	52	52	52	52	52	52	52	52		
Hydro	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	55	73	73	73	72	72	73	73	73	73	73		
Biomass	226	267	267	267	267	267	267	267	267	267	267	267	267	267	267	267	267	267	214	214	214	214	208	208	208	208		
Solar	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
Wind	48	48	48	48	39	39	39	39	43	43	43	43	43	34	34	34	34	14	13	13	13	13	23	23	23	23		
BESS	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
System Peak Demand (MW)	2,357	2,343	2,356	2,342	2,287	2,344	2,316	2,493	2,493	2,537	2,651	2,663	2,714	2,725	2,725	2,910	2,961	2,917	3,086	3,068	3,079	2,848	2,861	2,861	2,728	2,799		
Operating Margin (MW)	346	216	-126	33	270	339	354	61	125	-1	-218	-200	-24	52	155	-48	-81	-57	-280	-262	-273	-42	-51	-51	70	11		
Stranded Capacity (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
Net Operating Margin (MW)	346	216	0	33	270	339	354	61	125	0	0	0	0	52	155	0	0	0	0	0	0	0	0	0	70	11		
Req'd Regulating Reserve	94	94	94	94	91	94	93	100	100	101	106	107	109	109	109	116	118	117	123	123	123	114	114	114	109	112		
Req'd Contingency Reserve	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169		
Req'd Dispatchable Reserve	169	169	135	135	150	169	150	150	150	150	150	150	169	169	169	169	169	169	169	169	169	169	169	169	169	169		
Available Import from Luzon (HVDC)	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250		
Available Import from Mindanao (MVIP)	450	450	450	450	395	450	450	371	450	291	450	381	136	450	450	450	450	450	442	450	450	450	450	450	450	450		

- Peak Demand Forecast at 3,340 MW to occur in May 2026 based from the DOE Peak Demand Forecast 2020-2040.
- Preventive Maintenance of Power Plants considered.
- Embedded Generators considered.
- Evening Peak was considered in the outlook, hence, Solar Capacity not included.
- Capacity Factor for VRE Plants used: average of 17% for Solar and 22% for Wind (average of actual capacity for the previous year): Based on 24 hours
- The operating margin per week shown on the graph is based on the forecasted evening peak demand per week and its coincident available capacity.
- The Loss of Load Probability (LOLP) shown on the graph is derived with the consideration of capacity sharing among three regions and based on hourly projected peak demand. Hourly LOLP measures the probability that,
- The Probability of Yellow and Red Levels shown on the graph are derived with the consideration of capacity sharing among three regions and based on daily projected peak demand. Daily Probability of Yellow and Red
- Capacity addition per updates from DOE Visayas Power Committed Project as of June 30, 2024:
 - Ajuy 1 Solar Power Plant Project (14MW) - target date of commercial operation: January 2026
 - Luca Solar Power Project (80MW) - target date of commercial operation: September 2026
 - Silay 2b Solar Power Project (20MW) - target date of commercial operation: December 2026
 - Toledo Solar Power Project (49MW) - target date of commercial operation: December 2026
 - Silay 2a Solar Power Project (30MW) - target date of commercial operation: December 2026
 - Silay Solar Power Project (20MW) - target date of commercial operation: December 2026
 - Bago Wind Power Project (150MW) - target date of commercial operation: December 26, 2026
 - Iloilo CW 1 Wind Power Project (152MW) - target date of commercial operation: December 26, 2026
 - Gemini Wind Power Project (200MW) - target date of commercial operation: December 15, 2026
- Naga-Ormoc HVDC maintenance schedule is on October 23 - 29, 2026.
- Lala-Dumanjug HVDC maintenance schedule is on July 23 - 29, 2026 for Pole 1, August 20 - 26, 2026 for Pole 2, and September 23 - 29, 2026 for Bipole



VISAYAS GRID 2026 Weekly Demand, Supply and Operating Margin Profile Evening Peak Scenario with 450 MW Import from Mindanao




2026	JULY TO DECEMBER 2026																											
	Jun 29	Jul 06	Jul 13	Jul 20	Jul 27	Aug 03	Aug 10	Aug 17	Aug 24	Aug 31	Sep 07	Sep 14	Sep 21	Sep 28	Oct 05	Oct 12	Oct 19	Oct 26	Nov 02	Nov 09	Nov 16	Nov 23	Nov 30	Dec 07	Dec 14	Dec 21	Dec 28	
	Jul 05	Jul 12	Jul 19	Jul 26	Aug 02	Aug 09	Aug 16	Aug 23	Aug 30	Sep 06	Sep 13	Sep 20	Sep 27	Oct 04	Oct 11	Oct 18	Oct 25	Nov 01	Nov 08	Nov 15	Nov 22	Nov 29	Dec 06	Dec 13	Dec 20	Dec 27	Jan 03	
Available Generating Capacity (MW)	2,569	2,537	2,594	2,791	2,803	2,721	2,580	2,603	2,651	2,713	2,641	2,665	2,806	2,836	2,795	2,760	2,736	2,875	2,864	2,825	2,749	2,844	2,742	2,735	2,742	2,887	2,893	
Thermal	1,157	1,157	1,157	1,321	1,321	1,239	1,104	1,186	1,186	1,186	1,186	1,321	1,321	1,321	1,321	1,321	1,321	1,321	1,321	1,321	1,321	1,321	1,218	1,218	1,218	1,321	1,321	
Geothermal	797	747	797	834	834	834	834	769	834	834	769	704	834	834	798	834	804	834	834	798	726	798	798	798	798	834	834	
Diesel	276	276	276	280	280	288	282	280	273	282	276	224	235	277	272	201	207	288	277	288	277	293	293	287	293	300	300	
Power Barges	45	45	52	52	52	52	52	52	52	46	46	52	52	46	46	46	46	46	46	32	39	46	46	46	46	46	52	
Hydro	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	
Biomass	200	208	208	200	208	200	200	208	208	267	267	267	267	267	267	267	267	267	267	267	267	267	267	267	267	267	267	
Solar	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
Wind	22	31	31	31	35	35	35	35	25	25	25	25	25	19	19	19	19	47	47	47	47	47	47	47	47	47	47	
BESS	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
System Peak Demand (MW)	2,809	2,796	2,705	2,808	2,996	2,955	2,799	2,887	2,913	2,938	2,925	3,006	2,981	3,059	3,064	3,021	3,017	3,118	3,219	3,147	3,079	3,175	3,103	3,158	2,594	2,515	2,355	
Operating Margin (MW)	-240	-259	-111	-17	-193	-234	-219	-284	-262	-225	-284	-341	-175	-223	-269	-261	-281	-243	-355	-322	-330	-331	-361	-423	148	372	538	
Stranded Capacity (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Net Operating Margin (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	148	372	538	
Req'd Regulating Reserve	112	112	108	112	120	118	112	115	117	118	117	120	119	122	123	121	121	125	129	126	123	127	124	126	104	101	94	
Req'd Contingency Reserve	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	
Req'd Dispatchable Reserve	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	
Available Import from Luzon (HVDC)	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	0	250	250	250	250	250	250	250	250	250	250	
Available Import from Mindanao (MVIP)	450	450	450	225	450	450	399	225	450	314	348	350	0	139	322	223	110	312	357	213	256	303	375	241	450	450	450	

- Peak Demand Forecast at 3,340 MW to occur in May 2026 based from the DOE Peak Demand Forecast 2020-2040.
- Preventive Maintenance of Power Plants considered.
- Embedded Generators considered.
- Evening Peak was considered in the outlook, hence, Solar Capacity not included.
- Capacity Factor for VRE Plants used: average of 17% for Solar and 22% for Wind (average of actual capacity for the previous year): Based on 24 hours
- The operating margin per week shown on the graph is based on the forecasted evening peak demand per week and its coincident available capacity.
- The Loss of Load Probability (LOLP) shown on the graph is derived with the consideration of capacity sharing among three regions and based on hourly projected peak demand. Hourly LOLP measures the probability that, during a specific hour, the electricity
- The Probability of Yellow and Red Levels shown on the graph are derived with the consideration of capacity sharing among three regions and based on daily projected peak demand. Daily Probability of Yellow and Red Levels measures the probability that, at
- Capacity addition per updates from DOE Visayas Power Committed Project as of June 30, 2024:
 - Ajuy 1 Solar Power Plant Project (14MW) - target date of commercial operation: January 2026
 - Luca Solar Power Project (80MW) - target date of commercial operation: September 2026
 - Silay 2b Solar Power Project (20MW) - target date of commercial operation: December 2026
 - Toledo Solar Power Project (49MW) - target date of commercial operation: December 2026
 - Silay 2a Solar Power Project (30MW) - target date of commercial operation: December 2026
 - Silay Solar Power Project (20MW) - target date of commercial operation: December 2026
 - Bago Wind Power Project (150MW) - target date of commercial operation: December 26, 2026
 - Iloilo CW 1 Wind Power Project (152MW) - target date of commercial operation: December 26, 2026
 - Gemini Wind Power Project (200MW) - target date of commercial operation: December 15, 2026
- Naga-Ormoc HVDC maintenance schedule is on October 23 - 29, 2026.
- Lala-Dumanjug HVDC maintenance schedule is on July 23 - 29, 2026 for Pole 1, August 20 - 26, 2026 for Pole 2, and September 23 - 29, 2026 for Bipole

MINDANAO GRID

2026 Weekly Demand, Supply and Operating Margin Profile

450 MW Export to Visayas



2026	JANUARY TO JUNE 2026																											
	Dec 29	Jan 05	Jan 12	Jan 19	Jan 26	Feb 02	Feb 09	Feb 16	Feb 23	Mar 02	Mar 09	Mar 16	Mar 23	Mar 30	Apr 06	Apr 13	Apr 20	Apr 27	May 04	May 11	May 18	May 25	Jun 01	Jun 08	Jun 15	Jun 22		
	Jan 04	Jan 11	Jan 18	Jan 25	Feb 01	Feb 08	Feb 15	Feb 22	Mar 01	Mar 08	Mar 15	Mar 22	Mar 29	Apr 05	Apr 12	Apr 19	Apr 26	May 03	May 10	May 17	May 24	May 31	Jun 07	Jun 14	Jun 21	Jun 28		
Available Generating Capacity (MW)	3,497	3,510	3,509	3,267	3,250	3,262	3,252	3,276	3,478	3,262	3,243	3,156	3,296	3,488	3,478	3,478	3,399	3,460	3,487	3,487	3,416	3,466	3,601	3,559	3,541	3,546		
Coal	2,043	2,043	2,043	1,803	1,803	1,803	1,803	1,938	2,043	1,919	1,919	1,819	1,943	2,043	2,043	2,043	2,043	2,043	2,043	2,043	2,043	2,043	2,043	2,043	2,043	2,043		
Geothermal	102	102	102	102	102	102	102	102	102	98	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102		
Hydro	430	430	430	430	410	410	400	390	390	364	324	314	304	304	292	307	307	277	307	307	322	281	415	371	360	360		
Diesel	359	359	359	359	359	359	359	263	359	311	311	359	359	359	359	359	359	359	359	359	359	359	359	359	359	359		
Renewable	300	313	312	310	313	325	325	320	321	307	323	299	325	417	419	404	325	416	413	413	327	418	419	421	414	419		
BESS	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
Embedded	264	264	264	264	264	264	264	264	264	264	264	264	264	264	264	264	264	264	264	264	264	264	264	264	264	264		
System Peak Demand (MW)	2,300	2,430	2,579	2,443	2,635	2,641	2,516	2,660	2,594	2,725	2,638	2,625	2,731	2,714	2,882	2,942	2,925	2,746	2,975	2,928	2,862	2,872	2,782	2,788	2,780	2,791		
Operating Margin (MW)	1,197	1,080	931	824	615	622	736	615	883	538	604	531	565	774	596	536	473	714	512	559	554	594	819	771	761	755		
Net of MVIP Export (MW)	747	630	481	374	243	244	286	244	433	247	244	243	247	324	253	256	255	264	257	255	252	253	369	321	311	305		
Req'd Regulating Reserve	92	97	103	98	105	106	101	106	104	109	106	105	109	109	115	118	117	110	119	117	114	115	111	112	111	112		
Req'd Contingency Reserve	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138		
Req'd Dispatchable Reserve	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138		
MVIP Export (MW)	450	450	450	450	372	378	450	371	450	291	361	288	318	450	343	281	218	450	255	304	301	341	450	450	450	450		


- Peak Demand Forecast at 3,013 MW to occur in December 2026 based from the DOE Peak Demand Forecast 2020-2040
- Preventive Maintenance of Power Plants considered.
- Embedded Generators considered.
- Capacity Factor for VRE Plants used: 13-22% (average of actual capacity for previous year): Based on 24 hours
- The operating margin per week shown on the graph is based on the forecasted peak demand per week and its coincident available capacity.
- The Loss of Load Probability (LOLP) shown on the graph is derived with the consideration of capacity sharing among three regions and based on hourly projected peak demand. Hourly LOLP measures the probability that, during a
- The Probability of Yellow and Red Levels shown on the graph are derived with the consideration of capacity sharing among three regions and based on daily projected peak demand. Daily Probability of Yellow and Red Levels
- Capacity addition per updates from DOE Mindanao Power Committed Project as of June 30, 2024:
 - 8.1 Tantangan Solar Power Project (40MW) - target date of commercial operation: December 2026
- Lala-Dumanjug HVDC maintenance schedule is on July 23 - 29, 2026 for Pole 1, August 20 - 26, 2026 for Pole 2, and September 23 - 29, 2026 for Bipole



MINDANAO GRID

2026 Weekly Demand, Supply and Operating Margin Profile

450 MW Export to Visayas




2026	JULY TO DECEMBER 2026																											
	Jun 29	Jul 06	Jul 13	Jul 20	Jul 27	Aug 03	Aug 10	Aug 17	Aug 24	Aug 31	Sep 07	Sep 14	Sep 21	Sep 28	Oct 05	Oct 12	Oct 19	Oct 26	Nov 02	Nov 09	Nov 16	Nov 23	Nov 30	Dec 07	Dec 14	Dec 21	Dec 28	
	Jul 05	Jul 12	Jul 19	Jul 26	Aug 02	Aug 09	Aug 16	Aug 23	Aug 30	Sep 06	Sep 13	Sep 20	Sep 27	Oct 04	Oct 11	Oct 18	Oct 25	Nov 01	Nov 08	Nov 15	Nov 22	Nov 29	Dec 06	Dec 13	Dec 20	Dec 27	Jan 03	
Available Generating Capacity (MW)	3,516	3,274	3,391	3,298	3,341	3,392	3,177	3,183	3,100	3,239	3,140	3,222	3,305	3,352	3,211	3,177	3,178	3,394	3,420	3,405	3,412	3,408	3,371	3,438	3,565	3,565	3,552	
Coal	1,943	1,808	1,808	1,703	1,838	1,838	1,719	1,719	1,546	1,670	1,670	1,670	1,805	1,888	1,750	1,770	1,770	1,908	1,943	1,943	1,943	1,919	1,919	2,043	2,043	2,043	2,043	
Geothermal	98	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	
Hydro	449	449	479	469	469	429	429	389	429	429	422	412	452	412	412	407	407	437	416	401	416	432	391	351	462	462	462	
Diesel	359	359	359	359	359	352	256	304	352	359	359	359	359	359	359	311	311	359	359	359	359	359	359	359	359	359	359	
Renewable	421	314	400	419	328	419	419	419	419	419	328	419	328	328	325	324	325	325	337	337	337	332	336	320	336	336	324	
BESS	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
Embedded	246	242	244	246	246	253	253	250	253	260	260	260	260	264	264	264	264	264	264	264	256	264	264	264	264	264	264	
System Peak Demand (MW)	2,837	2,759	2,803	2,811	2,918	2,877	2,688	2,757	2,805	2,837	2,739	2,719	2,869	2,959	2,831	2,915	2,889	2,831	2,930	2,956	2,937	2,959	2,946	3,013	2,840	2,825	2,671	
Operating Margin (MW)	679	515	588	487	423	515	489	426	295	402	402	503	437	393	380	262	289	563	489	449	475	449	425	425	725	740	881	
Net of MVIP Export (MW)	251	248	250	262	198	253	246	201	250	251	248	247	437	393	251	255	254	251	255	256	255	256	256	259	275	290	431	
Req'd Regulating Reserve	113	110	112	112	117	115	108	110	112	113	110	109	115	118	113	117	116	113	117	118	117	118	118	121	114	113	107	
Req'd Contingency Reserve	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	
Req'd Dispatchable Reserve	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	
MVIP Export (MW)	427	267	338	225	225	262	244	225	45	150	154	256	0	0	129	8	35	312	234	193	219	193	169	166	450	450	450	

1. Peak Demand Forecast at 3,013 MW to occur in December 2026 based on the DOE Peak Demand Forecast 2020-2040
2. Preventive Maintenance of Power Plants considered.
3. Embedded Generators considered.
4. Capacity Factor for VRE Plants used: 13-22% (average of actual capacity for previous year): Based on 24 hours
5. The operating margin per week shown on the graph is based on the forecasted peak demand per week and its coincident available capacity.
6. The Loss of Load Probability (LOLP) shown on the graph is derived with the consideration of capacity sharing among three regions and based on hourly projected peak demand. Hourly LOLP measures the probability that, during a specific
7. The Probability of Yellow and Red Levels shown on the graph are derived with the consideration of capacity sharing among three regions and based on daily projected peak demand. Daily Probability of Yellow and Red Levels measures the
8. Capacity addition per updates from DOE Mindanao Power Committed Project as of June 30, 2024:
 - 8.1 Tantangan Solar Power Project (40MW) - target date of commercial operation: December 2026
9. Lala-Dumanjug HVDC maintenance schedule is on July 23 - 29, 2026 for Pole 1, August 20 - 26, 2026 for Pole 2, and September 23 - 29, 2026 for Bipole



LUZON GRID 2027 Weekly Demand, Supply and Operating Margin Profile




2027	JANUARY TO JUNE 2027																											
	Jan 04	Jan 11	Jan 18	Jan 25	Feb 01	Feb 08	Feb 15	Feb 22	Mar 01	Mar 08	Mar 15	Mar 22	Mar 29	Apr 05	Apr 12	Apr 19	Apr 26	May 03	May 10	May 17	May 24	May 31	Jun 07	Jun 14	Jun 21	Jun 28		
	Jan 10	Jan 17	Jan 24	Jan 31	Feb 07	Feb 14	Feb 21	Feb 28	Mar 07	Mar 14	Mar 21	Mar 28	Apr 04	Apr 11	Apr 18	Apr 25	May 02	May 09	May 16	May 23	May 30	Jun 06	Jun 13	Jun 20	Jun 27	Jul 04		
Available Generating Capacity (MW)	17,778	16,655	17,588	17,026	16,190	16,412	17,899	18,100	18,488	18,458	18,482	18,604	18,380	18,596	18,219	18,237	18,149	18,204	18,199	18,221	18,223	18,086	17,984	18,273	18,381	18,057		
Thermal	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
Coal	8,255	7,985	8,440	7,922	7,777	8,020	8,688	8,688	8,988	8,988	9,448	9,448	9,448	9,448	9,448	9,448	9,448	9,448	9,448	9,448	9,448	9,448	9,448	9,448	9,448	8,998		
Gas Turbine/Diesel	746	746	746	746	736	736	673	679	688	736	740	746	746	746	746	746	746	746	746	746	746	746	746	746	746	740		
Combined Cycle/NatGas	5,136	4,736	4,736	4,676	4,471	4,676	5,136	5,136	5,136	5,136	5,093	5,136	5,136	5,136	5,136	5,136	5,136	5,136	5,136	5,136	5,136	5,136	5,136	5,136	5,136	5,036		
Geothermal	487	457	457	457	457	380	380	467	447	447	447	447	467	467	467	461	481	481	487	487	487	487	447	487	487	487		
HVDC	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
Wind Farm	417	283	472	456	393	63	370	409	496	354	149	260	189	511	87	110	63	134	118	39	55	94	55	87	55	39		
Solar	464	535	499	535	642	464	606	678	678	678	713	678	713	606	571	642	678	678	713	678	713	606	606	642	642	571		
BESS	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
Biomass	95	95	95	95	101	101	101	101	107	107	107	107	103	103	107	107	107	107	107	107	107	107	88	88	107	107		
Hydro	2,179	1,819	2,144	2,140	1,614	1,974	1,946	1,943	1,949	2,013	1,785	1,783	1,578	1,579	1,659	1,587	1,491	1,476	1,445	1,581	1,531	1,462	1,458	1,640	1,761	2,080		
System Peak Demand (MW)	12,828	12,994	12,955	13,277	13,315	13,429	13,624	13,855	13,934	14,050	14,413	14,504	14,583	14,777	15,091	16,259	16,526	16,665	16,609	16,342	16,180	16,127	16,070	15,978	15,553	15,481		
Operating Margin (MW)	4,699	3,411	4,383	3,498	2,625	2,733	4,025	3,995	4,304	4,158	3,819	3,850	3,547	3,569	2,878	1,728	1,372	1,335	1,340	1,630	1,793	1,709	1,664	2,045	2,578	2,326		
Req'd Regulating Reserve	513	520	518	531	533	537	545	554	557	562	577	580	583	591	604	650	661	667	664	654	647	645	643	639	622	619		
Req'd Contingency Reserve	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668		
Req'd Dispatchable Reserve	668	668	668	647	647	647	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668		
HVDC Export (MW)	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	205	250	250	250	250	250	250	250	250		

- Peak Demand Forecast at 16,665 MW to occur in May 2027 based from the DOE Peak Demand Forecast 2020-2040
- Preventive Maintenance of Power Plants considered.
- Embedded Generators considered.
- Capacity Factor for VRE Plants used: average of 16% for Solar and 30% for Wind (average of actual capacity for 3 years: 2021 to 2023): Based on 24 hours
- Consideration of additional capacities of new VRE Plants
- The operating margin per week shown on the graph is based on the forecasted peak demand per week and its coincident available capacity.
- The Loss of Load Probability (LOLP) shown on the graph is derived with the consideration of capacity sharing among three regions and based on hourly projected peak demand. Hourly LOLP measures the probability that, during a specific hour, the electricity demand will exceed the available generation capacity.
- The Probability of Yellow and Red Levels shown on the graph are derived with the consideration of capacity sharing among three regions and based on daily projected peak demand. Daily Probability of Yellow and Red Levels measures the probability that, at any time during a particular day, there will be at least one hour where the demand exceeds the supply together with the regulating and contingency required reserve level.
- Capacity addition per updates from DOE Luzon Power Committed Project as of June 30, 2024:
 - 9.1 YH Camarines Norte Solar Power Plant (8 MW) - target date of commercial operation: December 2027
 - 9.2 Kalayaan 2 Wind Power Project (100.80 MW) - target date of commercial operation: December 01, 2027
- Naga-Ormoc HVDC maintenance schedule is on October 21 - 27, 2027.



LUZON GRID

2027 Weekly Demand, Supply and Operating Margin Profile



2027	JULY TO DECEMBER 2027																											
	Jul 05	Jul 12	Jul 19	Jul 26	Aug 02	Aug 09	Aug 16	Aug 23	Aug 30	Sep 06	Sep 13	Sep 20	Sep 27	Oct 04	Oct 11	Oct 18	Oct 25	Nov 01	Nov 08	Nov 15	Nov 22	Nov 29	Dec 06	Dec 13	Dec 20	Dec 27		
	Jul 11	Jul 18	Jul 25	Aug 01	Aug 08	Aug 15	Aug 22	Aug 29	Sep 05	Sep 12	Sep 19	Sep 26	Oct 03	Oct 10	Oct 17	Oct 24	Oct 31	Nov 07	Nov 14	Nov 21	Nov 28	Dec 05	Dec 12	Dec 19	Dec 26	Jan 02		
Available Generating Capacity (MW)	17,592	17,454	17,928	17,175	17,881	18,020	17,886	18,078	18,141	18,141	17,433	16,793	17,153	17,932	17,904	18,223	18,192	17,907	17,793	17,784	18,033	18,232	18,228	17,976	17,706	18,589		
Thermal	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
Coal	8,616	8,616	8,916	7,977	8,877	8,877	8,788	8,788	8,945	8,945	8,137	7,793	8,229	8,529	8,529	8,873	8,561	8,556	8,406	8,651	8,651	8,501	8,501	8,501	8,501	9,298		
Gas Turbine/Diesel	740	530	746	746	740	746	746	746	746	746	746	746	746	746	746	746	746	746	746	746	746	596	718	708	746	746		
Combined Cycle/NatGas	4,936	4,936	4,880	5,136	4,618	4,876	4,876	5,076	5,076	5,076	5,050	4,828	4,605	5,136	5,136	5,136	5,136	5,136	4,872	4,872	5,136	5,136	5,136	5,136	4,671	4,613		
Geothermal	465	465	465	465	465	465	465	487	487	487	487	380	487	487	487	487	487	487	487	487	487	487	487	487	487	487		
HVDC	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
Wind Farm	47	39	126	142	370	102	63	102	189	189	31	142	142	118	126	212	433	244	417	409	385	566	511	252	480	629		
Solar	606	535	464	357	464	606	606	535	357	357	642	571	606	571	535	428	499	678	606	535	499	642	571	571	499	499		
BESS	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
Biomass	107	107	107	107	101	101	101	101	99	99	99	99	99	107	107	107	107	107	107	107	107	88	88	107	107	107		
Hydro	2,076	2,227	2,225	2,246	2,246	2,246	2,241	2,243	2,243	2,242	2,236	2,239	2,239	2,239	2,235	2,224	1,954	2,152	1,978	2,022	2,216	2,216	2,216	2,216	2,210			
System Peak Demand (MW)	15,436	15,287	15,261	15,246	15,254	15,279	15,281	15,327	15,320	15,320	15,341	15,384	15,278	15,233	15,144	15,081	15,037	15,028	15,035	15,106	14,956	14,888	14,781	14,334	13,879	12,341		
Operating Margin (MW)	1,906	1,917	2,417	1,679	2,378	2,491	2,355	2,501	2,571	2,571	1,842	1,283	1,625	2,449	2,510	3,143	3,155	2,629	2,508	2,428	2,827	3,094	3,196	3,392	3,577	5,998		
Req'd Regulating Reserve	617	611	610	610	610	611	611	613	613	613	614	615	611	609	606	603	601	601	601	601	604	598	596	591	573	555	494	
Req'd Contingency Reserve	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668		
Req'd Dispatchable Reserve	668	668	668	647	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668	668		
HVDC Export (MW)	250	250	250	250	250	250	250	250	250	250	125	250	250	250	250	0	0	250	250	250	250	250	250	250	250	250		


- Peak Demand Forecast at 16,665 MW to occur in May 2027 based from the DOE Peak Demand Forecast 2020-2040
- Preventive Maintenance of Power Plants considered.
- Embedded Generators considered.
- Capacity Factor for VRE Plants used: average of 16% for Solar and 30% for Wind (average of actual capacity for 3 years: 2021 to 2023): Based on 24 hours
- Consideration of additional capacities of new VRE Plants
- The operating margin per week shown on the graph is based on the forecasted peak demand per week and its coincident available capacity.
- The Loss of Load Probability (LOLP) shown on the graph is derived with the consideration of capacity sharing among three regions and based on hourly projected peak demand. Hourly LOLP measures the probability that, during a specific hour, the electricity demand will exceed the available generation capacity.
- The Probability of Yellow and Red Levels shown on the graph are derived with the consideration of capacity sharing among three regions and based on daily projected peak demand. Daily Probability of Yellow and Red Levels measures the probability that, at any time during a particular day, there will be at least one hour where the demand exceeds the supply together with the regulating and contingency required reserve level.
- Capacity addition per updates from DOE Luzon Power Committed Project as of June 30, 2024:
 - 9.1 YH Camarines Norte Solar Power Plant (8 MW) - target date of commercial operation: December 2027
 - 9.2 Kalayaan 2 Wind Power Project (100.80 MW) - target date of commercial operation: December 01, 2027
- Naga-Ormoc HVDC maintenance schedule is on October 21 - 27, 2027.



VISAYAS GRID

2027 Weekly Demand, Supply and Operating Margin Profile

Afternoon Peak Scenario with 450 MW Import from Mindanao



2027	JANUARY TO JUNE 2027																											
	Jan 04	Jan 11	Jan 18	Jan 25	Feb 01	Feb 08	Feb 15	Feb 22	Mar 01	Mar 08	Mar 15	Mar 22	Mar 29	Apr 05	Apr 12	Apr 19	Apr 26	May 03	May 10	May 17	May 24	May 31	Jun 07	Jun 14	Jun 21	Jun 28		
	Jan 10	Jan 17	Jan 24	Jan 31	Feb 07	Feb 14	Feb 21	Feb 28	Mar 07	Mar 14	Mar 21	Mar 28	Apr 04	Apr 11	Apr 18	Apr 25	May 02	May 09	May 16	May 23	May 30	Jun 06	Jun 13	Jun 20	Jun 27	Jul 04		
Available Generating Capacity (MW)	3,039	2,736	2,811	2,976	2,962	2,962	2,963	3,208	3,236	3,160	3,019	3,111	3,150	3,253	3,253	3,253	3,206	3,154	3,154	3,154	3,154	3,131	3,131	3,109	3,117	2,847		
Thermal	1,171	1,002	1,002	1,152	1,070	1,070	1,070	1,321	1,321	1,239	1,136	1,218	1,218	1,321	1,321	1,321	1,321	1,321	1,321	1,321	1,321	1,321	1,321	1,321	1,321	1,136		
Geothermal	834	747	791	791	828	828	829	791	828	834	797	834	834	834	834	834	834	834	834	834	834	834	834	834	834	765		
Diesel	346	300	331	346	346	346	346	346	336	336	336	336	346	346	346	346	346	346	346	346	346	346	346	346	346	317		
Power Barges	52	52	52	52	52	52	52	45	45	45	45	52	52	52	52	52	52	52	52	52	52	52	52	52	52	52		
Hydro	73	73	73	73	73	73	73	73	73	73	73	73	73	73	72	73	72	73	73	73	73	73	73	73	73	73		
Biomass	267	267	267	267	267	267	267	267	267	267	267	232	267	267	267	267	267	214	214	214	214	208	208	200	208	208		
Solar	215	215	215	215	252	252	252	288	288	288	288	288	301	301	301	301	276	276	276	276	276	246	246	232	232	241		
Wind	82	82	82	82	75	75	75	78	78	78	78	78	60	60	60	60	38	38	38	38	38	51	51	51	51	56		
BESS	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
System Peak Demand (MW)	2,592	2,512	2,670	2,643	2,575	2,650	2,614	2,749	3,001	2,910	3,072	3,195	3,228	3,268	3,343	3,435	3,494	3,522	3,568	3,583	3,585	3,397	3,399	3,334	3,249	3,294		
Operating Margin (MW)	447	224	141	333	387	312	349	459	235	250	-53	-84	-78	-15	-90	-182	-288	-368	-414	-429	-431	-266	-268	-225	-132	-447		
Stranded Capacity (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
Net Operating Margin (MW)	447	224	141	333	387	312	349	459	235	250	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
Req'd Regulating Reserve	104	100	107	106	103	106	105	110	120	116	123	128	129	131	134	137	140	141	143	143	143	136	136	133	130	132		
Req'd Contingency Reserve	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169		
Req'd Dispatchable Reserve	169	169	169	150	150	150	150	150	150	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169		
Available Import from Luzon (HVDC)	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	239	250	250	250	250	250	250	250	250		
Available Import from Mindanao (MVIP)	450	450	387	450	335	450	450	450	450	169	450	450	450	450	450	450	416	450	385	450	450	450	450	450	450	450		


1. Peak Demand Forecast at 3,585 MW to occur in May 2027 based from the DOE Peak Demand Forecast 2020-2040.
2. Preventive Maintenance of Power Plants considered.
3. Embedded Generators considered.
4. Capacity Factor for VRE Plants used: average of 17% for Solar and 22% for Wind (average of actual capacity for the previous year): Based on 24 hours
5. The operating margin per week shown on the graph is based on the forecasted afternoon peak demand per week and its coincident available capacity.
6. The Loss of Load Probability (LOLP) shown on the graph is derived with the consideration of capacity sharing among three regions and based on hourly projected peak demand. Hourly LOLP measures the probability that, during a specific hour, the electricity demand will exceed the available generation capacity.
7. The Probability of Yellow and Red Levels shown on the graph are derived with the consideration of capacity sharing among three regions and based on daily projected peak demand. Daily Probability of Yellow and Red Levels measures the probability that, at any time during a particular day, there will be at least one hour where the demand exceeds the supply together with the regulating and contingency required reserve level.
8. Capacity addition per updates from DOE Visayas Power Committed Project as of June 30, 2024:
 - 8.1 Biliran Geothermal Plant Project (Phase 3) (42MW) - target date of commercial operation: January 2027
9. Naga-Ormoc HVDC maintenance schedule is on October 21 - 27, 2027.
10. Lala-Dumanjug HVDC maintenance schedule is on July 21 - 27, 2027 for Pole 1, August 20 - 26, 2027 for Pole 2, and September 23 - 29, 2027 for Bipole.



VISAYAS GRID

2027 Weekly Demand, Supply and Operating Margin Profile

Afternoon Peak Scenario with 450 MW Import from Mindanao



2027	JULY TO DECEMBER 2027																											
	Jul 05	Jul 12	Jul 19	Jul 26	Aug 02	Aug 09	Aug 16	Aug 23	Aug 30	Sep 06	Sep 13	Sep 20	Sep 27	Oct 04	Oct 11	Oct 18	Oct 25	Nov 01	Nov 08	Nov 15	Nov 22	Nov 29	Dec 06	Dec 13	Dec 20	Dec 27		
	Jul 11	Jul 18	Jul 25	Aug 01	Aug 08	Aug 15	Aug 22	Aug 29	Sep 05	Sep 12	Sep 19	Sep 26	Oct 03	Oct 10	Oct 17	Oct 24	Oct 31	Nov 07	Nov 14	Nov 21	Nov 28	Dec 05	Dec 12	Dec 19	Dec 26	Jan 02		
Available Generating Capacity (MW)	2,835	2,838	3,127	3,135	3,072	3,040	3,019	2,967	3,063	3,147	3,095	2,997	3,051	3,051	2,906	2,902	3,108	3,193	3,102	3,194	3,124	3,073	3,090	3,183	3,195	3,202		
Thermal	1,136	1,136	1,321	1,321	1,321	1,239	1,239	1,239	1,321	1,321	1,321	1,186	1,186	1,186	1,104	1,104	1,239	1,321	1,321	1,321	1,321	1,239	1,239	1,321	1,321	1,321		
Geothermal	765	765	834	834	769	834	834	769	733	798	798	834	834	834	834	834	834	834	744	834	834	834	834	834	834	834		
Diesel	328	316	335	340	325	312	318	318	314	333	281	276	322	322	264	272	342	329	321	317	329	306	323	333	340	346		
Power Barges	45	52	52	52	52	45	45	52	46	46	46	52	52	52	52	52	45	39	46	52	52	46	46	46	52	52		
Hydro	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73		
Biomass	200	208	208	200	208	208	208	208	267	267	267	267	267	267	267	267	267	267	267	267	267	267	267	267	267	267		
Solar	225	225	241	250	258	263	236	250	248	248	248	248	261	261	255	247	230	250	250	250	250	228	228	228	228	228		
Wind	63	63	63	66	66	66	66	58	62	62	62	62	58	58	58	53	78	81	81	81	81	81	81	81	81	81		
BESS	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
System Peak Demand (MW)	3,351	3,287	3,234	3,347	3,445	3,445	3,355	3,415	3,455	3,433	3,499	3,486	3,387	3,513	3,438	3,401	3,376	3,419	3,496	3,482	3,446	3,414	3,235	3,384	2,743	2,872		
Operating Margin (MW)	-516	-449	-107	-212	-373	-405	-336	-448	-392	-286	-404	-489	-336	-462	-532	-499	-268	-226	-394	-288	-322	-341	-145	-201	452	330		
Stranded Capacity (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
Net Operating Margin (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	452	330		
Req'd Regulating Reserve	134	131	129	134	138	138	134	137	138	137	140	139	135	141	138	136	135	137	140	139	138	137	129	135	110	115		
Req'd Contingency Reserve	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169		
Req'd Dispatchable Reserve	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169		
Available Import from Luzon (HVDC)	250	250	250	250	250	250	250	250	250	250	250	70	250	250	250	0	250	250	250	250	250	250	250	250	250	250		
Available Import from Mindanao (MVIP)	450	442	225	450	67	285	450	286	187	164	320	450	0	345	450	450	336	227	169	255	450	412	298	296	450	450		


1. Peak Demand Forecast at 3,585 MW to occur in May 2027 based from the DOE Peak Demand Forecast 2020-2040.
2. Preventive Maintenance of Power Plants considered.
3. Embedded Generators considered.
4. Capacity Factor for VRE Plants used: average of 17% for Solar and 22% for Wind (average of actual capacity for the previous year): Based on 24 hours
5. The operating margin per week shown on the graph is based on the forecasted afternoon peak demand per week and its coincident available capacity.
6. The Loss of Load Probability (LOLP) shown on the graph is derived with the consideration of capacity sharing among three regions and based on hourly projected peak demand. Hourly LOLP measures the probability that, during a specific hour, the electricity demand will exceed the available generation capacity.
7. The Probability of Yellow and Red Levels shown on the graph are derived with the consideration of capacity sharing among three regions and based on daily projected peak demand. Daily Probability of Yellow and Red Levels measures the probability that, at any time during a particular day, there will be at least one hour where the demand exceeds the supply together with the regulating and contingency required reserve level.
8. Capacity addition per updates from DOE Visayas Power Committed Project as of June 30, 2024:
 - 8.1 Biliran Geothermal Plant Project (Phase 3) (42MW) - target date of commercial operation: January 2027
9. Naga-Ormoc HVDC maintenance schedule is on October 21 - 27, 2027.
10. Lala-Dumanjug HVDC maintenance schedule is on July 21 - 27, 2027 for Pole 1, August 20 - 26, 2027 for Pole 2, and September 23 - 29, 2027 for Bipole.



VISAYAS GRID

2027 Weekly Demand, Supply and Operating Margin Profile

Evening Peak Scenario with 450 MW Import from Mindanao




2027	JANUARY TO JUNE 2027																											
	Jan 04	Jan 11	Jan 18	Jan 25	Feb 01	Feb 08	Feb 15	Feb 22	Mar 01	Mar 08	Mar 15	Mar 22	Mar 29	Apr 05	Apr 12	Apr 19	Apr 26	May 03	May 10	May 17	May 24	May 31	Jun 07	Jun 14	Jun 21	Jun 28		
	Jan 10	Jan 17	Jan 24	Jan 31	Feb 07	Feb 14	Feb 21	Feb 28	Mar 07	Mar 14	Mar 21	Mar 28	Apr 04	Apr 11	Apr 18	Apr 25	May 02	May 09	May 16	May 23	May 30	Jun 06	Jun 13	Jun 20	Jun 27	Jul 04		
Available Generating Capacity (MW)	2,824	2,521	2,607	2,762	2,879	2,699	2,705	2,920	2,947	2,871	2,731	2,822	2,849	2,952	2,952	2,952	2,930	2,878	2,878	2,878	2,878	2,885	2,885	2,885	2,885	2,607		
Thermal	1,171	1,002	1,002	1,152	1,239	1,070	1,070	1,321	1,321	1,239	1,136	1,218	1,218	1,321	1,321	1,321	1,321	1,321	1,321	1,321	1,321	1,321	1,321	1,321	1,321	1,136		
Geothermal	834	747	797	791	828	828	823	791	828	834	797	834	834	834	834	834	834	834	834	834	834	834	834	834	834	765		
Diesel	346	300	336	346	346	335	346	346	336	336	336	336	346	346	346	346	346	346	346	346	346	346	346	346	346	317		
Power Barges	52	52	52	52	52	52	52	45	45	45	45	52	52	52	52	52	52	52	52	52	52	52	52	52	52	52		
Hydro	73	73	73	73	73	73	73	73	73	73	73	73	73	73	72	72	72	73	73	73	73	73	73	73	73	73		
Biomass	267	267	267	267	267	267	267	267	267	267	267	232	267	267	267	267	267	214	214	214	214	208	208	208	208	208		
Solar	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
Wind	82	82	82	82	75	75	75	78	78	78	78	78	60	60	60	60	38	38	38	38	38	51	51	51	51	56		
BESS	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
System Peak Demand (MW)	2,531	2,516	2,530	2,515	2,456	2,517	2,488	2,659	2,678	2,725	2,849	2,861	2,916	2,928	3,053	3,126	3,179	3,268	3,312	3,294	3,305	3,059	3,073	2,992	2,930	3,007		
Operating Margin (MW)	293	5	77	247	423	182	217	261	269	146	-118	-39	-67	24	-101	-174	-249	-390	-434	-416	-427	-174	-188	-107	-45	-400		
Stranded Capacity (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
Net Operating Margin (MW)	293	5	77	247	423	182	217	261	269	146	0	0	0	24	0	0	0	0	0	0	0	0	0	0	0	0		
Req'd Regulating Reserve	101	101	101	101	98	101	100	106	107	109	114	114	117	117	122	125	127	131	132	132	132	122	123	120	117	120		
Req'd Contingency Reserve	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169		
Req'd Dispatchable Reserve	169	169	169	150	150	150	150	150	150	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169		
Available Import from Luzon (HVDC)	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	239	250	250	250	250	250	250	250	250		
Available Import from Mindanao (MVIP)	450	450	387	450	335	450	450	450	450	169	450	450	450	450	450	450	416	450	385	450	450	450	450	450	450	450		

- Peak Demand Forecast at 3,585 MW to occur in May 2027 based from the DOE Peak Demand Forecast 2020-2040.
- Preventive Maintenance of Power Plants considered.
- Embedded Generators considered.
- Evening Peak was considered in the outlook, hence, Solar Capacity not included.
- Capacity Factor for VRE Plants used: average of 17% for Solar and 22% for Wind (average of actual capacity for the previous year): Based on 24 hours
- The operating margin per week shown on the graph is based on the forecasted evening peak demand per week and its coincident available capacity.
- The Loss of Load Probability (LOLP) shown on the graph is derived with the consideration of capacity sharing among three regions and based on hourly projected peak demand. Hourly LOLP measures the probability that, during a specific hour, the electricity demand will exceed the available generation capacity.
- The Probability of Yellow and Red Levels shown on the graph are derived with the consideration of capacity sharing among three regions and based on daily projected peak demand. Daily Probability of Yellow and Red Levels measures the probability that, at any time during a particular day, there will be at least one hour where the demand exceeds the supply together with the regulating and contingency required reserve level.
- Capacity addition per updates from DOE Visayas Power Committed Project as of June 30, 2024:
 - 9.1 Biliran Geothermal Plant Project (Phase 3) (42MW) - target date of commercial operation: January 2027
- Naga-Ormoc HVDC maintenance schedule is on October 21 - 27, 2027.
- Lala-Dumanjug HVDC maintenance schedule is on July 21 - 27, 2027 for Pole 1, August 20 - 26, 2027 for Pole 2, and September 23 - 29, 2027 for Bipole.



VISAYAS GRID 2027 Weekly Demand, Supply and Operating Margin Profile Evening Peak Scenario with 450 MW Import from Mindanao



2027	JULY TO DECEMBER 2027																											
	Jul 05	Jul 12	Jul 19	Jul 26	Aug 02	Aug 09	Aug 16	Aug 23	Aug 30	Sep 06	Sep 13	Sep 20	Sep 27	Oct 04	Oct 11	Oct 18	Oct 25	Nov 01	Nov 08	Nov 15	Nov 22	Nov 29	Dec 06	Dec 13	Dec 20	Dec 27		
	Jul 11	Jul 18	Jul 25	Aug 01	Aug 08	Aug 15	Aug 22	Aug 29	Sep 05	Sep 12	Sep 19	Sep 26	Oct 03	Oct 10	Oct 17	Oct 24	Oct 31	Nov 07	Nov 14	Nov 21	Nov 28	Dec 05	Dec 12	Dec 19	Dec 26	Jan 02		
Available Generating Capacity (MW)	2,610	2,613	2,886	2,886	2,814	2,732	2,782	2,717	2,816	2,900	2,848	2,750	2,790	2,790	2,651	2,655	2,878	2,943	2,853	2,944	2,874	2,845	2,862	2,954	2,967	2,974		
Thermal	1,136	1,136	1,321	1,321	1,321	1,239	1,239	1,239	1,321	1,321	1,321	1,186	1,186	1,186	1,104	1,104	1,239	1,321	1,321	1,321	1,239	1,239	1,239	1,321	1,321	1,321		
Geothermal	765	765	834	834	769	784	834	769	733	798	798	834	834	834	834	834	834	834	744	834	834	834	834	834	834	834		
Diesel	328	316	335	340	325	325	318	318	314	333	281	276	322	322	264	272	342	329	322	317	329	306	323	326	340	346		
Power Barges	45	52	52	52	52	45	52	52	46	46	46	52	52	52	52	52	45	39	46	52	52	46	46	52	52	52		
Hydro	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73		
Biomass	200	208	208	200	208	200	200	208	267	267	267	267	267	267	267	267	267	267	267	267	267	267	267	267	267	267		
Solar	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
Wind	63	63	63	66	66	66	66	58	62	62	62	62	58	58	58	53	78	81	81	81	81	81	81	81	81	81		
BESS	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
System Peak Demand (MW)	3,018	3,003	2,907	3,016	3,080	3,173	3,006	3,101	3,128	3,155	3,142	3,259	3,201	3,373	3,328	3,320	3,347	3,400	3,367	3,416	3,393	3,408	3,307	3,390	2,787	3,029		
Operating Margin (MW)	-408	-390	-21	-130	-266	-441	-224	-384	-312	-255	-294	-509	-411	-583	-677	-665	-469	-457	-514	-472	-519	-563	-445	-436	180	-55		
Stranded Capacity (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
Net Operating Margin (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	180	0		
Req'd Regulating Reserve	121	120	116	121	123	127	120	124	125	126	126	130	128	135	133	133	134	136	135	137	136	136	132	136	111	121		
Req'd Contingency Reserve	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169		
Req'd Dispatchable Reserve	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169		
Available Import from Luzon (HVDC)	250	250	250	250	250	250	250	250	250	250	250	70	250	250	250	0	250	250	250	250	250	250	250	250	250	250		
Available Import from Mindanao (MVIP)	450	442	225	450	67	285	450	286	187	164	320	450	0	345	450	450	336	227	169	255	450	412	298	296	450	450		


1. Peak Demand Forecast at 3,585 MW to occur in May 2027 based from the DOE Peak Demand Forecast 2020-2040.
2. Preventive Maintenance of Power Plants considered.
3. Embedded Generators considered.
4. Evening Peak was considered in the outlook, hence, Solar Capacity not included.
5. Capacity Factor for VRE Plants used: average of 17% for Solar and 22% for Wind (average of actual capacity for the previous year): Based on 24 hours
6. The operating margin per week shown on the graph is based on the forecasted evening peak demand per week and its coincident available capacity.
7. The Loss of Load Probability (LOLP) shown on the graph is derived with the consideration of capacity sharing among three regions and based on hourly projected peak demand. Hourly LOLP measures the probability that, during a specific hour, the electricity demand will exceed the available generation capacity.
8. The Probability of Yellow and Red Levels shown on the graph are derived with the consideration of capacity sharing among three regions and based on daily projected peak demand. Daily Probability of Yellow and Red Levels measures the probability that, at any time during a particular day, there will be at least one hour where the demand exceeds the supply together with the regulating and contingency required reserve level.
9. Capacity addition per updates from DOE Visayas Power Committed Project as of June 30, 2024:
 - 9.1 Biliran Geothermal Plant Project (Phase 3) (42MW) - target date of commercial operation: January 2027
10. Naga-Ormoc HVDC maintenance schedule is on October 21 - 27, 2027.
11. Lala-Dumanjug HVDC maintenance schedule is on July 21 - 27, 2027 for Pole 1, August 20 - 26, 2027 for Pole 2, and September 23 - 29, 2027 for Bipole.



MINDANAO GRID

2027 Weekly Demand, Supply and Operating Margin Profile

450 MW Export to Visayas



2027	JANUARY TO JUNE 2027																									
	Jan 04	Jan 11	Jan 18	Jan 25	Feb 01	Feb 08	Feb 15	Feb 22	Mar 01	Mar 08	Mar 15	Mar 22	Mar 29	Apr 05	Apr 12	Apr 19	Apr 26	May 03	May 10	May 17	May 24	May 31	Jun 07	Jun 14	Jun 21	Jun 28
	Jan 10	Jan 17	Jan 24	Jan 31	Feb 07	Feb 14	Feb 21	Feb 28	Mar 07	Mar 14	Mar 21	Mar 28	Apr 04	Apr 11	Apr 18	Apr 25	May 02	May 09	May 16	May 23	May 30	Jun 06	Jun 13	Jun 20	Jun 27	Jul 04
Available Generating Capacity (MW)	3,566	3,574	3,436	3,419	3,436	3,544	3,533	3,534	3,240	3,144	3,309	3,450	3,424	3,466	3,515	3,523	3,491	3,502	3,488	3,509	3,470	3,524	3,575	3,587	3,531	3,565
Coal	2,043	2,043	1,908	1,908	1,908	2,043	2,043	2,043	1,819	1,819	1,919	2,043	2,043	2,043	2,043	2,043	2,043	2,043	2,043	2,043	2,043	2,043	2,043	2,043	2,043	2,043
Geothermal	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	98
Hydro	430	430	430	410	430	400	389	390	364	324	324	314	277	262	322	322	292	307	292	307	281	322	371	385	360	385
Diesel	359	359	359	359	359	359	359	359	352	311	359	359	359	359	359	359	359	359	359	359	359	359	359	359	359	352
Renewable	320	328	325	329	326	329	329	329	310	284	300	328	332	388	377	386	383	379	380	387	374	387	388	387	368	386
BESS	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Embedded	312	312	312	312	312	312	312	312	294	305	305	305	312	312	312	312	312	312	312	312	312	312	312	312	300	302
System Peak Demand (MW)	2,739	2,631	2,791	2,779	2,854	2,856	2,724	2,818	2,881	2,949	2,855	2,827	2,957	2,938	3,118	3,183	3,165	2,973	3,219	3,167	3,097	3,113	3,010	3,017	3,009	3,022
Operating Margin (MW)	827	943	645	640	582	688	809	716	359	196	454	623	467	528	397	340	325	529	269	342	373	411	564	570	523	543
Net of MVIP Export (MW)	377	493	250	249	252	252	359	266	253	256	274	443	287	348	263	265	265	349	267	265	262	263	384	390	343	363
Req'd Regulating Reserve	110	105	112	111	114	114	109	113	115	118	114	113	118	118	125	127	127	119	129	127	124	125	120	121	120	121
Req'd Contingency Reserve	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138
Req'd Dispatchable Reserve	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138
MVIP Export (MW)	450	450	395	391	330	436	450	450	376	210	450	450	450	450	404	345	331	450	272	348	381	418	450	450	450	450


- Peak Demand Forecast at 3,259 MW to occur in December 2027 based from the DOE Peak Demand Forecast 2020-2040
- Preventive Maintenance of Power Plants considered.
- Embedded Generators considered.
- Capacity Factor for VRE Plants used: 13-22% (average of actual capacity for previous year): Based on 24 hours
- The operating margin per week shown on the graph is based on the forecasted peak demand per week and its coincident available capacity.
- The Loss of Load Probability (LOLP) shown on the graph is derived with the consideration of capacity sharing among three regions and based on hourly projected peak demand. Hourly LOLP measures the probability that, during a specific hour, the electricity demand will exceed the available generation capacity.
- The Probability of Yellow and Red Levels shown on the graph are derived with the consideration of capacity sharing among three regions and based on daily projected peak demand. Daily Probability of Yellow and Red Levels measures the probability that, at any time during a particular day, there will be at least one hour where the demand exceeds the supply together with the regulating and contingency required reserve level.
- Capacity addition per updates from DOE Mindanao Power Committed Project as of June 30, 2024:
 - 8.1 Misamis Oriental Circulating Fluidized Bed Coal Fired Thermal Power Plant (2x135MW) - target date of commercial operation: March 2027
- Lala-Dumanjung HVDC maintenance schedule is on July 21 - 27, 2027 for Pole 1, August 20 - 26, 2027 for Pole 2, and September 23 - 29, 2027 for Bipole.



MINDANAO GRID

2027 Weekly Demand, Supply and Operating Margin Profile

450 MW Export to Visayas



2027	JULY TO DECEMBER 2027																									
	Jul 05	Jul 12	Jul 19	Jul 26	Aug 02	Aug 09	Aug 16	Aug 23	Aug 30	Sep 06	Sep 13	Sep 20	Sep 27	Oct 04	Oct 11	Oct 18	Oct 25	Nov 01	Nov 08	Nov 15	Nov 22	Nov 29	Dec 06	Dec 13	Dec 20	Dec 27
	Jul 11	Jul 18	Jul 25	Aug 01	Aug 08	Aug 15	Aug 22	Aug 29	Sep 05	Sep 12	Sep 19	Sep 26	Oct 03	Oct 10	Oct 17	Oct 24	Oct 31	Nov 07	Nov 14	Nov 21	Nov 28	Dec 05	Dec 12	Dec 19	Dec 26	Jan 02
Available Generating Capacity (MW)	3,637	3,403	3,256	3,310	3,397	3,218	3,377	3,292	3,103	3,137	3,247	3,417	3,405	3,591	3,566	3,521	3,426	3,327	3,468	3,326	3,572	3,527	3,527	3,503	3,598	3,585
Coal	2,043	1,808	1,708	1,708	1,808	1,670	1,770	1,646	1,511	1,646	1,784	1,905	1,905	2,043	2,023	2,023	1,918	1,838	1,938	1,838	2,043	2,043	2,043	2,043	2,043	2,043
Geothermal	52	52	52	52	52	52	102	102	102	102	102	98	102	102	102	102	102	102	102	98	102	102	102	102	102	102
Hydro	509	509	469	509	494	494	454	494	432	357	332	357	347	442	442	397	407	391	431	391	432	391	391	367	462	462
Diesel	352	352	352	352	359	311	359	359	359	359	359	359	359	359	359	359	359	359	359	359	359	359	359	359	359	359
Renewable	382	383	372	385	383	386	387	386	387	361	358	386	380	333	329	329	328	325	326	328	325	328	328	328	328	315
BESS	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Embedded	301	300	305	305	302	306	306	306	312	312	312	312	312	312	312	312	312	312	312	312	312	305	305	305	305	305
System Peak Demand (MW)	3,070	2,985	3,034	3,042	3,159	3,112	2,909	2,984	3,039	3,070	2,963	2,943	3,104	3,201	3,063	3,153	3,126	3,066	3,170	3,197	3,178	3,105	3,187	3,259	3,073	2,741
Operating Margin (MW)	567	418	223	268	238	106	468	308	64	68	284	474	301	390	503	368	300	261	298	129	394	422	340	244	525	844
Net of MVIP Export (MW)	387	257	259	260	264	262	288	257	260	261	257	744	571	266	323	264	263	261	265	266	265	262	265	268	345	664
Req'd Regulating Reserve	123	119	121	122	126	124	116	119	122	123	119	118	124	128	123	126	125	123	127	128	127	124	127	130	123	110
Req'd Contingency Reserve	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138
Req'd Dispatchable Reserve	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138
MVIP Export (MW)	450	431	233	278	244	113	450	320	75	77	298	0	0	394	450	374	307	271	303	134	399	429	344	246	450	450

- Peak Demand Forecast at 3,259 MW to occur in December 2027 based from the DOE Peak Demand Forecast 2020-2040
- Preventive Maintenance of Power Plants considered.
- Embedded Generators considered.
- Capacity Factor for VRE Plants used: 13-22% (average of actual capacity for previous year): Based on 24 hours
- The operating margin per week shown on the graph is based on the forecasted peak demand per week and its coincident available capacity.
- The Loss of Load Probability (LOLP) shown on the graph is derived with the consideration of capacity sharing among three regions and based on hourly projected peak demand. Hourly LOLP measures the probability that, during a specific hour, the electricity demand will exceed the available generation capacity.
- The Probability of Yellow and Red Levels shown on the graph are derived with the consideration of capacity sharing among three regions and based on daily projected peak demand. Daily Probability of Yellow and Red Levels measures the probability that, at any time during a particular day, there will be at least one hour where the demand exceeds the supply together with the regulating and contingency required reserve level.
- Capacity addition per updates from DOE Mindanao Power Committed Project as of June 30, 2024:
 - Misamis Oriental Circulating Fluidized Bed Coal Fired Thermal Power Plant (2x135MW) - target date of commercial operation: March 2027
- Lala-Dumanjug HVDC maintenance schedule is on July 21 - 27, 2027 for Pole 1, August 20 - 26, 2027 for Pole 2, and September 23 - 29, 2027 for Bipole.