

ANCILLARY SERVICE REQUIREMENTS

In compliance with the Energy Regulatory Commission's (ERC) Order dated 01 December 2022, NGCP is posting the Ancillary Service Requirements and the existing Firm & Non-Firm contracted capacities as of **August 2026**:

Grid	REGULATING RESERVE				
	Required	Valid ASPAs (prior to CSP)		New ASPAs from CSP	Implemented ASPAs from CSP as of Aug. 25, 2026 (Ave. MW)
		Firm	Non-firm	Firm (Ave. MW)	
Luzon	627	0	0	257.78	257.78
Visayas	134	40	0	N/A	N/A
Mindanao	121	0	0**	68.61	68.61

*NPC Plants are certified only under Governor Control Mode (GCM) of operation.

Grid	CONTINGENCY RESERVE				
	Required	Valid ASPAs (prior to CSP)		New ASPAs from CSP	Implemented ASPAs from CSP as of Aug. 25, 2026 (Ave. MW)
		Firm	Non-firm	Firm (Ave. MW)	
Luzon	668	0	0	376.7	376.7
Visayas	150	0	0	83.44	83.44
Mindanao	138	0	210.7	80.71	80.71

Grid	DISPATCHABLE RESERVE				
	Required	Valid ASPAs (prior to CSP)		New ASPAs from CSP	Implemented ASPAs from CSP as of Aug. 25, 2026 (Ave. MW)
		Firm	Non-firm	Firm (Ave. MW)	
Luzon	668	0	0	191.10	187.8
Visayas	150	0	0	44.27	5.5
Mindanao	138	7.5	0	129.15	129.15

Grid	REACTIVE POWER SUPPORT (No. of Units Contracted)		BLACK START SERVICE (Total MW)	
	Valid ASPAs (Prior to CSP)	New ASPAs from CSP	Valid ASPAs (Prior to CSP)	New ASPAs from CSP
Luzon	11	6	0	180
Visayas	0	16	0	184.5
Mindanao	0	18	225	196

Please note that the values remain the same since June 2026.

In summary, thirty-four (34) out of the thirty-six (36) ASPA Applications under the 2023 Competitive Selection Process (CSP) have been approved and issued with Final Authority by the ERC.

As of date, two (2) ASPAs were not implemented despite receipt of ERC Provisional Authority, while one (1) ASPA has been filed for termination as requested by the AS Provider. The details are as follows:

- CIP II Power Corp. - Dispatchable Reserve in Luzon which has a pending Motion for Reconsideration filed with the ERC requesting for the re-evaluation of the interim approved rates and a Motion for the Termination of the ASPA.
- SPC Island Power Corporation - Dispatchable Reserve & Black Start Service for Visayas which has a pending Motion for the Termination of the ASPA.
- Therma Visayas Inc. – Contingency Reserve and Reactive Power Support Service for Visayas which has a pending Urgent Motion for Termination due to business decision.

NGCP is awaiting the final decision on the filed Motions with the ERC, which are still pending for its resolution.

Meanwhile, seven (7) ASPAs recently contracted under the 2026 CSP have been filed with the ERC for the issuance of Provisional Authority.