

ANCILLARY SERVICE REQUIREMENTS

In compliance with the Energy Regulatory Commission’s (ERC) Order dated 01 December 2022, NGCP is posting the Ancillary Service Requirements and the existing Firm & Non-Firm contracted capacities as of **April 2025**:

Grid	REGULATING RESERVE				
	Required	Valid ASPAs (prior to CSP)		New ASPAs from CSP	Implemented ASPAs from CSP as of Mar. 26, 2025 (Ave. MW)
		Firm	Non-firm	Firm (Ave. MW)	
Luzon	591	45	135	257.78	257.78
Visayas	124	40	0	N/A	N/A
Mindanao	112	0	165	68.61	68.61

Grid	CONTINGENCY RESERVE				
	Required	Valid ASPAs (prior to CSP)		New ASPAs from CSP	Implemented ASPAs from CSP as of Mar. 26, 2025 (Ave. MW)
		Firm	Non-firm	Firm (Ave. MW)	
Luzon	668	0	90	376.7	376.7
Visayas	153	0	0	83.44	83.44
Mindanao	138	0	201	80.71	66.96

Grid	DISPATCHABLE RESERVE				
	Required	Valid ASPAs (prior to CSP)		New ASPAs from CSP	Implemented ASPAs from CSP as of Mar. 26, 2025 (Ave. MW)
		Firm	Non-firm	Firm (Ave. MW)	
Luzon	668	0	360	191.10	187.8
Visayas	153	0	0	44.27	5.5
Mindanao	138	7.5	0	129.15	129.15

In summary, all of the thirty-six (36) ASPA Applications under the Competitive Selection Process (CSP) have been approved by the ERC, with thirty-three (33) ASPAs implemented. Meanwhile, two (2) ASPAs have yet to be implemented despite receipt of ERC approval, as NGCP is awaiting the final decision of the AS Providers for the ASPA implementation considering its filed Motions with the ERC. Also, one (1) ASPA is undergoing finalization of the guidelines for implementation:

- CIP II Power Corp. - Dispatchable Reserve in Luzon which has a pending Motion for Reconsideration filed with the ERC requesting for the re-evaluation of the interim approved rates and Motion for the Termination of the ASPA.
- SPC Island Power Corporation - Dispatchable Reserve & Black Start Service for Visayas which has a pending Motion for the Termination of the ASPA.

- GN Power Kauswagan Ltd. Co. - Contingency Reserve for Mindanao, in which guidelines for ASPA implementation is undergoing finalization.

Grid	REACTIVE POWER SUPPORT (No. of Units Contracted)		BLACK START SERVICE (Total MW)	
	Valid ASPAs (Prior to CSP)	New ASPAs from CSP	Valid ASPAs (Prior to CSP)	New ASPAs from CSP
Luzon	18	6	813	180
Visayas	0	22	0	225
Mindanao	12	18	225	196

Please note that the values remain the same since March 2025.

This Customer Bulletin was prepared by the Customer Affairs Department of Revenue and Regulatory Affairs. For any questions/inquiries, you may e-mail us at lgbacani@ngcp.ph or rcereno@ngcp.ph.